

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO.F6/DFS/MS/2018/SZ/ 2626

Dated: 6/12/18

FIRE SAFETY CERTIFICATE

Certified that the Maa Vindhyvasini Sewa Sansthan, HAF, Pocket-2, Sector-17, Dwarka, New Delhi-110075, comprised of basement stilt/ground plus two upper floors, owned/occupied by Maa Vindhyvasini Sewa Sansthan was issued fire safety certificate by this department vide letter no.F6/DFS/MS//2015/SZ/1370 dated 30.07.2015. The premises was re-inspected by the officer concerned of this department on 14.11.2018 in the presence of Sh. Surinder Dhar Shastri (President) and found that the premises have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service 2010, and that the premises/ building is fit for occupancy class Group-D Assembly "Building" (Temple) with effect from...6/12/18... for a period of **three** years subject to compliance of the conditions printed overleaf.

Issued on6/12/18..... at New Delhi by

VC
JK
Vipin Kental
Chief Fire Officer
JK

Copy to:-

1. The Jt. Director (L&I), Bldg, DDA Bldg Section, Vikas Sadan, INA, New Delhi.
2. Maa Vindhyvasini Sewa Sansthan, HAF, Pocket-2, Sector-17, Dwarka, New Delhi-110075.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	Maa Vindhyvasini Sewa Sansthan, HAF, Pocket-2, Sector-17, Dwarka, New Delhi-110075		
2	Type of Occupancy	Assembly Building "D" (Temple)		
3	Type of case	Renewal (basement, Stilt/ground plus two upper floors)		
4	Details of previous NOC	F/6/DFS/MS/2015/SZ/1370 dated 30.07.2015		
5	Fire safety directives letter No	F/6/DFS/MS/BP/2013/374 dated 24.01.2013		
6	Date of inspection	14.11.2018		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh. Surinder Dhar Shashtri (President)		
9	Year of construction	2015		
10	Applicant's letter No.	Nil Dated 23.10.2018	Basement Stilt/ Ground plus two upper Floors.	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	30 Mtrs.	Provided	MR
	2) Gate width	6 Mtrs.	Provided	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	Two	Two	MR
	2. basements	One	One	MR
	b. Width of staircase			
	1. Upper floors	2 Mtrs.	1.77 Mtrs. Basement to 2nd floor, 1.50 Mtrs. Stilt to first floor	MR being old case
	2. basements	2 Mtrs.	1.70 Mtrs.	MR
	c. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	One	Provided	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	2 Mtrs.	Provided	MR
3	Compartmentation.			
	1. Fire check door	Required	Provided	MR
	2. Sealing of electrical shafts	Required	Provided	MR
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	30 a/c per hour	Exhaust fans Provided	MR
	upper floors	12 a/c per hour	Natural Vent.	MR
5	Fire Extinguishers			
	total numbers	08 Nos.	Provided	MR
	Types	CO2 & ABC	Provided	MR
		ICM	Provided	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	One	Provided	MR
	Length of Hose reel hose	30 m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	basement	Required	Provided	MR
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	100 mm	Provided	MR
	Number of Hydrants per floor	One	Provided	MR
	hose Box	Required	Provided	MR
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	1620 LPM	Provided	MR
	b. head of the pump	35 Mtrs.	Provided	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	25000 Ltrs.	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

N/14

17	Standby power supply	Required	DG Set 62.5 KVA	MR
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	
	d. Batter backup	Required	Provided	MR
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	Required	ABC fire extinguisher near electrical panel	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view the deemed compliance of minimum standards on fire prevention and fire safety requirements as under the rules, renewal of fire Certificate issued vide letter no.F6/DFS/MS/2015/SZ/1370 dated 30.07.2015 is recommended.

Accordingly DFA is put up for approval and signature please.

S.P. Bhardwaj
 S.P. Bhardwaj
 ADO Dwarka
 15/11/18

DOSW

166/DOSW
 dt. 22/11/18

20/11/18

DCFO (S2) - on leave

CFOS2

218/CFOS2
 20/11/18

M. S cell

FTD1.
30/11

FT is put up for signature please

CFOS2

31/11/18

M. S cell
4/11