

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/EH/2018/WZ/ 2656

Dated: 10/12/18

FIRE SAFETY CERTIFICATE

Certified that the Mc Donald's Family Restaurant located at 23, West Punjabi Bagh, Central Market, New Delhi was issued Fire Safety Certificate vide Letter No. F6/DFS/MS/EH/2015/WZ/2235 dated 23/12/2015 at Basement, Ground & 1st Floor in a building comprised of Basement, Ground & Three Upper Floors. The premises was re-inspected by the officer concerned of this department on dated 26/11/2018 in presence of Mr. Ravinder Singh (Manager) & found that building have deemed complied with the Fire Prevention and Fire Safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for class D (Assembly) occupancy with effect from.....10/12/18.. for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 10/12/18 at New Delhi by.


(ATUL GARG)
CHIEF FIRE OFFICER.


Copy to :-

1. Authorized Signatory, Mc Donald's Family Restaurant, **Connaught Plaza Restaurants Private Limited**, Corp. Off. 13A, Jor Bagh Market, New Delhi-110003.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. This NOC / FSC valid for Ground + 1st Floor only.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: Mc Donald's Family Restaurant located at 23, West Punjabi Bagh, Central Market, New Delhi. Basement, Ground & 1st Floor in a building comprised of Basement, Ground & Three Upper Floors.
2. Type of Occupancy : Assembly (Restaurant)
3. Type of Case : Renewal
4. Fire Safety directives Letter No. : F6/DFS/MS/EH/2015/WZ/2235 dated 23/12/2015
5. Date of inspection : 26/11/2018
6. Name of the Inspecting Officer : A. K.-Jaiswal A.D.O. (Jwp.)
7. Name and designation of Officer
from the building side : Mr. Ravinder Singh (Manager)
8. Year of Construction : 2006-07
9. Applicant's letter No. : -Nil DATED 26/10/18

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Part-IV Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr.	6 mtr.	MR
	• Gate width	4.5 mtr.	On Road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1	1	MR
	• Basements	2	2	MR
	b. Width of staircases			
	• Upper floors	Old Case	90CM	MR being old case
	• Basements	Old Case	90CM	MR being old case
	c. Protection of exits			
	• Fire check door	Required	provided	MR
	• Pressurization	NR	NR	NR
	d. No of continuous staircase to terrace	1	1	MR
	e. Width Of Corridor	NR	NR	NR
	f. Door Size	Old Case	1.5 approx	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NR	NR	NR
	• Fire Rating of shaft door	NR	NR	NR
	• Water Curtain	NR	NR	NR
	• Fire Dampers	NR	NR	NR
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	10	12	M/R
	• Types	ISI marked ABC/CO ₂	Provided	M/R
	• IS marking	Required	Provided	M/R

(Signature)

6.	First - Aid Hose Reels			
	• Total numbers on each floor	One	One	MR
	• Length of hose reel hose	30mtr.	30mtr.	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	Smoke	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NR	NR	NR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	No false ceiling	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	NR	NR	NR
	• Number of hydrants per floor	NR	NR	NR
	• Hose Box	NR	NR	NR
12.	Yard Hydrants			
	• Total number of hydrants	NR	NR	NR
	• Hose Box	NR	NR	NR
13.	Pumping Arrangements			
	• Ground Level	N/A		
	• Discharge of main pump	NR	NR	NR
	➤ Head of main pump	NR	NR	NR
	➤ Number of main pumps	NR	NR	NR
	➤ Jockey pump out put	NR	NR	NR
	➤ Jockey pump head	NR	NR	NR
	➤ Standby Pump out put	NR	NR	NR
	➤ Standby Pump Head	NR	NR	NR
	➤ Auto Starting/Manual stopping	NR	NR	NR
	➤ Pump House Access	NR	NR	NR
	• Terrace level			
	➤ Discharge of pump	Old Case	450 & 220 LPM	MR
	➤ Head of the pump	45 MH	45 MH	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NR	NR	NR
	➤ Draw of connection	NR	NR	NR
	➤ Fire service inlet	NR	NR	NR
	➤ Access to tank	NR	NR	NR
	• Overhead Tank	NR	NR	NR

N120

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NR	NR	NR
	➤ Pressurization of lift lobby	NR	NR	NR
	➤ Communication in lift Car	NR	NR	NR
	➤ Fireman's Grounding Switch	NR	NR	NR
	➤ Lift Signage	NR	NR	NR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/EH/2015/WZ/2235/dated 23/12/2015 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

D. d./s (W D)

Ashok Kumar Jaiswal
25/11/18

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (Jwala Puri)

Ashok Kumar Jaiswal
4/12/18

D. d./s (W 2)

[Signature]
6/12/18

cto. west
[Signature]

F.T.P.s

F.T. is put up for sign. phase.

[Signature]

Ashok
10/12/18

CFO / CO 2 / *[Signature]*
10/12/18

M