

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2018/ 511/2657

Dated: 10/12/18

FIRE SAFETY CERTIFICATE

Certified that the Mc Donald's Family Restaurant at G-1, Block-G, Pushkar Enclave, Pashim Vihar, New Delhi-110063 was granted NOC / FSC by the department vide letter No. F6/DFS/MS/WZ/2015/EH/2141 dated 04/12/2015. The premises was re-inspected by the officer concerned of this department on dated 26/11/2018 in presence of Mr. Ankur (Manager) & found that building have deemed complied with the Fire Prevention and Fire Safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for class D (Assembly) occupancy with effect from.....10/12/18... for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 10/12/18 at New Delhi by.


(ATUL GARG)
CHIEF FIRE OFFICER.

Copy to :-

1. Authorized Signatory, Mc Donald's Family Restaurant, **Connaught Plaza Restaurants Private Limited**, Corp. Off. 13A, Jor Bagh Market, New Delhi-110003.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

N/15

1. Name & address of the building: Mc Donald's Family Restaurant, G-1, Block-G,
Pushkar Enclave, Pashim Vihar, New Delhi-110063.
2. Type of Occupancy : Assembly (Restaurant)
3. Type of Case :Renewal
4. Fire Safety directives Letter No. : F6/DFS/MS/WZ/2015/EH/2141/dated 04/12/2015
5. Date of inspection : 26/11/2018
6. Name of the Inspecting Officer : A. K.-Jaiswal A.D.O. (Jwp.)
7. Name and designation of Officer
from the building side : Mr. Ankur (Manager)
8. Year of Construction : 2006-07
9. Applicant's letter No. : -Nil DATED 26/10/18

Ground Floor + One Upper only
Plot Area :- 1215 m ²
Covered Area GF :- 416m ² , FF :-296m ²

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Part-IV Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 mtr.	12 mtr.	MR
	• Gate width	4.5 mtr.	4.5 mtr.	MR
	• Width of internal road	As per sanction Plan	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	Restaurant at Ground Floor Only	2	MR
	• Basements	2	3	MR
	b. Width of staircases			
	• Upper floors	Restaurant at Ground Floor Only	NA	NA
	• Basements	1.50mtr.	1.50mtr,1.20 mtr,&1.25mtr	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NR	NR	NR
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	Halls Only	Halls Only	MR
	f. Door Size	1.50 mtr x 2	1.50 mtr x 2	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NR	NR	NR
	• Fire Rating of shaft door	NR	NR	NR
	• Water Curtain	NR	NR	NR
	• Fire Dampers	NR	NR	NR
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	Restaurant at Ground Floor Only	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	4	12	M/R
	• Types	ISI marked ABC/CO ₂	Provided	M/R
	• IS marking	Required	Provided	M/R

6.	First – Aid Hose Reels			
	• Total numbers on each floor	One	One	MR
	• Length of hose reel hose	30mtr.	30mtr.	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	Smoke	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NR	NR	NR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	(Restaurant at Ground floor only)	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants			
	• Size of riser/down-comer	NR	NR	NR
	• Number of hydrants per floor	NR	NR	NR
	• Hose Box	NR	NR	NR
12.	Yard Hydrants			
	• Total number of hydrants	NR	NR	NR
	• Hose Box	NR	NR	NR
13.	Pumping Arrangements			
	• Ground Level	N/A		
	• Discharge of main pump	NR	NR	NR
	➤ Head of main pump	NR	NR	NR
	➤ Number of main pumps	NR	NR	NR
	➤ Jockey pump out put	NR	NR	NR
	➤ Jockey pump head	NR	NR	NR
	➤ Standby Pump out put	NR	NR	NR
	➤ Standby Pump Head	NR	NR	NR
	➤ Auto Staring/Manual stopping	NR	NR	NR
	➤ Pump House Access	NR	NR	NR
	• Terrace level			
	➤ Discharge of pump	900 LPM	900 LPM	MR
	➤ Head of the pump	60 MH	60 MH	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NR	NR	NR
	➤ Draw of connection	NR	NR	NR
	➤ Fire service inlet	NR	NR	NR
		NR	NR	NR

		Required	Provided	MR
15	Exit Signage			
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NR	NR	NR
	➤ Pressurization of lift lobby	NR	NR	NR
	➤ Communication in lift Car	NR	NR	NR
	➤ Fireman's Grounding Switch	NR	NR	NR
	➤ Lift Signage	NR	NR	NR
17.	Standby power supply	NR	NR	NR
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:- MCB / ELCB and metal conduit wiring (Concealed Type) have been Provided.
The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/WZ/2015/EH/2141/dated 04/12/2015 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

DO (COD)

[Signature]
4/12/18

~~Dy. CEO (WZ)~~

[Signature]
6/12/18

~~CEO West~~

F.T. DLG

~~Asst. CD~~ F.T. is put up for signature pl.

~~CEO (WZ) Ashok Kumar Jaiswal~~
10/12/18

[Signature]
29/11/18

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (Jwala Puri)

[Signature]
10/12/18