

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F.6/DFS/MS/WZ/2018/ BNQT/2669

Dated: 10/12/2018

FIRE SAFETY CERTIFICATE

Certified that the **Mehak Banquet, Located at Upper Ground Floor & First Floor, 43, Road No. 35, Rohtak Road, West Punjabi Bagh, New Delhi – 110026.** in a building comprised of Basement + Stilt + Upper Ground + 3 Upper Floors owned/occupied by **Mehak Banquet** was issued FSC vide Letter No. F.6/DFS/MS/WZ/BNQT/2015/2143 Dated-08/12/2015, The premises was re inspected by the officers concerned of this department on **04-12-2018** in the presence of **Sh. Naveen (Manager)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class “ Assembly” Group D (**Upper Ground Floor & First Floor**) with effect from 10/12/18 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...10/12/18..... at New Delhi by.


(Atul Garg)
Chief Fire Officer,
Delhi Fire Service.

Copy to:

1. The Mehak Banquet, Upper Ground Floor & First Floor, 43, Road No. 35, Rohtak Road, West Punjabi Bagh, New Delhi – 110026.
2. The Dy. Health Officer (West Zone), South Delhi Municipal Corporation, Rajouri Garden, New Delhi – 110027.

Following fire safety directives must be adhered to:-

1. **FSC is valid for Upper Ground and First Floor only.**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expire

INSPECTION REPORT

1. Name & address of the building: Mehak Banquet, Upper Ground Floor & First Floor, 43, Road No. 35, Rohtak Road, West Punjabi Bagh, New Delhi – 110026.
2. Type of Occupancy : Assembly (Basement + Stilt + Upper Ground + 3 Upper Floors) Height = 14.75m.
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/WZ/BNQT/2015/2143 Dated- 08/12/2015
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 04-12-2018
7. Name of the Inspecting Officer : Udai vir Singh ADO (WP)
8. Name and designation of Officer
from the building side : Sh. Naveen (Manager)
9. Year of Construction : 2014
10. Applicant's letter No. : Nil Dated 14-11-2018

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 m	Provided	MR
	• Gate width	5 m	On Main Road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	3 Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1X2m, 1X1.5m	1X205cm, 1X1m, 1X1.5 m	MR
	• Basements	NA	150 cm, 156 cm	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NR	NR	NR
	d. No of continuous staircase to terrace	1	2 Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2X2m	UGF (3 exits) – 205 cm, 200 cm, 168cm, FF (2 exits) – 200 cm, 200 cm	MR

3.	Compartmentation			
	• Fire check door	NR	NR	NR
	• Sealing of electrical shafts	NR	NR	NR
	• Fire Rating of shaft door	NR	NR	NR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	08 nos.	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NR	Provided	MR
	• Sprinkler above false ceiling	NR	Provided	MR
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	1	Provided	MR
	• Hose Box	1	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NR	NR	NR
	• Hose Box	NR	NR	NR

13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NR	2280 lpm Provided	MR
		NR	70 m Provided	MR
		NR	1 Provided	MR
		NR	180 lpm Provided	MR
		NR	70 m Provided	MR
		NR	NR	NR
		NR	NR	NR
		NR	NR	NR
		NR	NR	NR
		900 lpm	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NR	54,000 litres	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		15, 000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NR	NR	NR (as lift is terminating at stilt floor)
		NR	NR	NR
		Required	Provided	MR
		NR	Provided	NR
		NR	NR	NR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA
		NA	NA	NA
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F.6/DFS/MS/WZ/BNQT/2015/2143 Dated-08/12/2015 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

~~Signature of the Inspecting Officer~~

Name Uday Vir Singh
 Designation ASO/WP

Signature of the Inspecting Officer

Name
 Designation

~~DO (W)~~

~~Signature~~
 4/12/18

~~Dy. CFO (W2)~~

~~Signature~~
 6/12/18

~~CFO. West~~
 5/12/18

Dy. W F.T. letter is put up for signature please.

~~CFO (W2)~~
 8/12/18

~~Signature~~
 7/12/18

~~push~~