

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE, NEW DELHI

No. F6/MS/DFS/EH/SZ/2018/ 2629

Dated: 06.12.2018

FIRE SAFETY CERTIFICATE

Certified that M/s Pa-Pa-Ya Restaurant (A Unit of Massive Restaurants P Ltd) (Formerly B Bar) located at Level-4, Atrium, Select City Walk Mall, A-3, District Centre, Saket, New Delhi-110017, comprised of 03 tier basement, ground plus six upper floors was issued FSC by this department vide letter No. F6/DFS/MS/EH/2015/SZ/1508, dated 18.08.2015. The premises was re-inspected by the officer concerned of this department on 29.08.2018 in the presence of Mr. Zorawar Kalra (Manager) and found that the said premises have been deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Assembly, Group-D" (Eating House) as above with effect from the date of issue of this certificate for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed as under.

Issued on 06/12/18 2018 at New Delhi by.


(Vipin Kental)
Chief Fire Officer,
Ph: 011 - 23412225.

Copy to:

1. Auth. Signatory, M/s Pa-Pa-Ya Restaurant Level-4, Atrium, Select City Walk Mall, A-3, District Centre, Saket, New Delhi-110017.
2. DHO, South MCD, Public Health Department, South Zone, Green Park, New Delhi-110015.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape arrangements shall be kept unlocked and unobstructed for speedy evacuation of occupants in case of an emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT				
1	Name & Address of the Building	M/s Pa Pa Ya (A Unit of Massive Restaurants) at Level-4, Atrium, Select City Walk Mall, A-3, District Centre, Saket, New Delhi-110017		
2	Type of Occupancy	Assembly, "Group-D" (Eating House)		
3	Building Comprised of	3 Tier Basement, Ground + 6 upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/MS/DFS/EH/2015/SZ/1508 Dated 18-08-2015		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	29-08-2018		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Sh. Zorawar Kalra (Manager)		
10	Year of construction	2007 Restt running at 4 th level of the building.		
11	Applicant letter No.	Outdoor Diary No. 11661 dated 14-08-2018		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.	F6/DFS/MS/Mall/SZ/2018/585 dated 04-04-2018		
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Restt located within Mall	As above	MR
			As above	-NA-
			As above	-NA-
2	Number, width, type & arrangement of exits.	Provided & Maintained by Mall Management		
	a) Number of Staircase	02 Nos	As above	MR
	➤ Upper floors.	-NA-	As above	-NA-
	➤ Basement floor.			
	b) Width of Staircase	Provided & Maintained by Mall Management		
	➤ Upper floors	1.5 mtr	As above	MR
	➤ Basement floor	-NA-	As above	-NA-
	c) Protection of exits	Provided & Maintained by Mall Management		
	➤ Fire check door	Required	As above	MR
	➤ Pressurization	Required	As above	MR
	d) No. of continuous staircase to terrace	Required	As above	MR
	e) Width of corridor	Required	As above	MR
	f) Door size	2.0m	2m & 1.5m	MR
3	Compartmentation.	Provided & Maintained by Mall Management		
	<ul style="list-style-type: none"> Fire check door. Sealing of electrical shafts. Fire rating of shaft door. Water curtain Fire dampers. 	Required	As above	MR
		Required	As above	MR
		-NA-	As above	-NA-
		-NA-	As above	-NA-
		-NA-	As above	-NA-
4.	Smoke Management system.	Provided & Maintained by Mall Management		
	<ul style="list-style-type: none"> Basement Upper floors / Restt. premise 	30 ACPH	-NA-	-NA-
		12 ACPH	Exhaust fan provided	MR
5.	Fire Extinguishers.	Provided & Maintained by Mall Management		
	<ul style="list-style-type: none"> Total numbers Types ISI Marking 	Required	06 Nos	MR
		ABC / CO2	ABC & CO2	MR
		ISI marked	Provided	MR
6.	First Aid Hose Reels.	Provided & Maintained by Mall Management		
	<ul style="list-style-type: none"> Total numbers on each floor. Length of hose-reel hose. Nozzle Diameter 	One	As above	MR
		30 mtr	As above	MR
		5 mm	As above	MR

M/s Pa-Pa-Ya Restt at Level-4, Atrium, Select City Walk, A-3, District Centre, Saket, New Delhi

7	Automatic fire detection & alarming system.	Provided & Maintained by Mall Management		
	• Type of detectors	Required	As above	MR
	• Location of Main Panel	Required	As above	MR
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	Required	As above	MR
	• Hooter's location	Required	As above	MR
8.	MOEFA	Required	As above	MR
9.	Public Address System	-NA-	As above	-NA-
10.	Automatic Sprinkler System	Provided & Maintained by Mall Management		
	• Basement	-NA-	As above	-NA-
	• Upper floors / Restt premise	Required	As above	MR
	• Sprinkler above false ceiling	-NA-	As above	-NA-
11.	Internal Hydrants.	Provided & Maintained by Mall Management		
	• Size of Riser/Down-comer	Required	As above	MR
	• Number of Hydrant per floor	Required	As above	MR
	• Hose box.	Required	As above	MR
12.	Yard Hydrants.	Provided & Maintained by Mall Management		
	• Total number of hydrants.	-NA-	As above	-NA-
	• Hose box.	-NA-	As above	-NA-
13.	Pumping arrangements.	Provided & Maintained by Mall Management		
	• Ground Level	Provided & Maintained by Mall Management		
	➤ Discharge of main pump.	-NA-	4500 LPM	-NA-
	➤ Head of main pump.	-NA-	88 mtr	-NA-
	➤ Number of main pumps.	-NA-	Two	-NA-
	➤ Jockey Pump output.	-NA-	180 LPM	-NA-
	➤ Jockey Pump head.	-NA-	88 mtr	-NA-
	➤ Standby Pump output.	-NA-	4500 LPM	-NA-
	➤ Standby Pump head.	-NA-	88 mtr	-NA-
	➤ Auto Starting/Manual Stopping.	-NA-	Provided	-NA-
	➤ Pump house access.	-NA-	Provided	-NA-
	• Terrace Level	Provided & Maintained by Mall Management		
	➤ Discharge of pump.	450 LPM	As above	MR
	➤ Head of pump.	40m	As above	MR
	➤ Power supply.	Required	As above	MR
	➤ Auto starting of pump.	Required	As above	MR
14.	Captive water storage for fire fighting.	Provided & Maintained by Mall Management		
	• Underground tank capacity.	-NA-	5,00,000 Ltr	-NA-
	➤ Draw-off connection.	-NA-	As above	-NA-
	➤ Fire Service Inlet.	-NA-	As above	-NA-
	➤ Access to tank.	-NA-	As above	-NA-
	• Overhead tank capacity.	5,000 Ltr.	As above	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.	Provided & Maintained by Mall Management		
	• Pressurization of lift shaft.	-NA-	As above	-NA-
	• Pressurization of lift lobby.	-NA-	As above	-NA-
	• Communication in lift car.	-NA-	As above	-NA-
	• Fireman's switch.	-NA-	As above	-NA-
	• Lift signage.	-NA-	As above	-NA-
17.	Standby Power Supply	Required	Provided	MR
18.	Refuge Area	Provided & Maintained by Mall Management		
	• Total area	-NA-	958.78m ²	-NA-
	• Location	-NA-	4 th & 6 th Floor	-NA-

M/s Pa-Pa-Ya Restt at Level-4, Atrium, Select City Walk, A-3, District Centre, Saket, New Delhi

N/ 14

19.	Fire Control Room.	Provided & Maintained by Mall Management		
		<ul style="list-style-type: none"> • Detector system panel. • Flow switch panel. • PA system panel. • Battery backup. • Building floor plan. 	-NA-	As above
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	As above	-NA-
		-NA-	As above	-NA-
		-NA-	As above	-NA-
		-NA-	As above	-NA-
		-NA-	As above	-NA-

The fire protection system provided in the building/ premises were test checked at random and found functional at the time of inspection. Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F6/MS/DFS/EH/2015/SZ/1508 dated 18/08/2015, renewal under rule 37 of the Delhi Fire Service Rules 2010, is recommended.

Accordingly DFA is put up for approval and signature please.

[Signature]
 Signature of the Inspecting Officer
 Name: Mehmood
 Design: ADO (SJ)

M/s Pa-Pa-Ya Restt at Level-4, Atrium, Select City Walk, A-3, District Centre, Saket, New Delhi

~~DO (SD)~~

[Signature]
 30/11/18

[Signature]
 5/12

[Signature]
 4/12

[Signature] M.Scell FTB
 5/12

2301 CFO (S2)
 6/12/18

FT letter is put up for sign please
[Signature]
 6/12/18
 ADO (R/W)

