

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2018 / 2638

Dated: 7 / 12 / 2018

FIRE SAFETY CERTIFICATE

Certified that the **Rukmini Devi Public School** located at **B-5, Sector-4, Rohini, Delhi-110085** comprised of **Basement + Ground + 2 upper floor** owned/ occupied by the Rukmini Devi Public School was granted FSC by this department vide letter **F6/DFS/MS/2008/2608** dated **16/09/2008 (B+G+01upper floor)**. The premises was re-inspected by the officer concerned of this department and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rule, 2010 and verified by the officer concerned of fire service on **14.06.2018** in the presence of **Dr. Parveen Gupta, Principal** and that the building/ premise is fit for occupancy "**Group B Educational**" with effect from **..7/12/18**..... for a period of **three years**, in accordance with rule 36 unless under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules, 2010:

Conditions for the validity of Fire Safety Certificate:

8. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
9. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
10. The trained fire fighting staff should be available round the clock.
11. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
12. This certificate cannot be treated in any case for regularizations of unauthorized construction.
13. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
14. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on ...**7/12/18**..... at New Delhi


(Atul Garg)

Chief Fire Officer

Ph:-011-23414250

Copy to: -

3. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.
4. The Principal, Rukmini Devi Public School, B-5, Sector-4, Rohini, Delhi-110085.

INSPECTION REPORT

1. Name & address of the building : Rukmini Devi Public School, B-5, Sector-4, Rohini, Delhi-110085.
2. Type of Occupancy : Educational
3. Type of Case : Renewal, Add/alt. (B+G+02 upper floors)
4. Details of previous NOC : F6/DFS/MS/2008/2608 Dated: 16.09.2008
5. Fire Safety directives letter No : NBC Part-4
6. Date of inspection : 26.11.2018
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers
from the building side : Dr. Parveen Gupta (Principal)
9. Year of Construction : 2002/2014
10. Applicant's letter No. : No. RDPS/2018-19/610 dated: 03.10.2018

Plot Area-1000 m²

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part 4	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	06m	MR
	• Gate width	4.5m	4.0m	MR(old case)
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	02	02	MR
	b. Width of staircases			
	• Upper Floors	1.50m	1.50m & 1.15 m	MR
	• Basements	1.50m	1.50m & 1.15 m	MR
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.0 m	1 m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA

A

2/17

	<ul style="list-style-type: none"> • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	Exhaust Fan	MR
		12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI marking 	08 nos	09nos	MR
		ABC/CO2	ABC—09	MR
		ISI Marked	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	01	01	MR
		30m	30m	MR
		5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	Required	Provided	MR
		01	01	MR
		01	01	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA	Provided	NA
		NA	NA	NA
13	Pumping Arrangements.			

h

	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		450lpm & 180 lpm	450 lpm & 180 lpm	MR	
		40m	40m	MR	
		Required	Provided	MR	
		Required	Provided	MR	
	14	Captive Water Storage for fire fighting.			
		<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		10,000 ltrs	10,000 ltrs	MR	
15	Exit Signage.	Required	Provided	MR	
16	Provision of Lifts.				
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
17	Standby power supply	NA	NA	NA	
18	Refuge Area.				
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A	
		N/A	N/A	N/A	
19	Fire Control Room				
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel 	NA	NA	NA	
		N/A	N/A	N/A	



N/19

	<ul style="list-style-type: none"> PA System Panel Batter backup Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition, at the time of inspection. The management has complied all the shortcomings issued and communicated by this department vide letter of even no. 3963 dated 19.09.2018.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part 4, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. 2608 dated 16.09.2008(B+G+01upper floor) under DFS Rules, 2010.

RK
28/11

Signature of the Inspecting Officer
Name: - Rajesh Kumar
Designation: - ADO/RN

Director
CFO West
A/B/11

[Signature]
30/11/18
F.T.P.I

ADO/RN

As approved, F.T. letter is put up for your signature P.I.

CFO West
A/B/11
me

RK
5/12