

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No.F6/DFS/MS/School/2018/NDZ/ 2719


Dated: 17/12/18

FIRE SAFETY CERTIFICATE

Certified that the AVB Adarsh Vidya Bhawan at F-277-278, Laxmi Nagar, Delhi-92, owned/occupied by AVB Adarsh Vidya Bhawan, Comprised of ground plus two upper floors was granted FSC vide letter F6/MS/DFS/School/2015/NDZ/2012 dated-06/11/15. The school building was inspected by the officer concerned of this department on 04/12/18 in the presence of Sh. Pankaj Verma (Manager) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010 and that the building is fit for occupancy class B "Educational Building" with effect from 17/12/18 for a period of **three** years, subject to conditions printed overleaf.

Issued on 17/12/18 at New Delhi by


(Vipin Kental)
Chief Fire Officer
Delhi Fire Service



To,

The Manager,
AVB Adarsh Vidya Bhawan,
F-277-278, Laxmi Nagar, Delhi-92.

Copy to:-

1 The Director of Education,
EDMC,419,Udyog Sadan,
Patparganj Industrial Area,Delhi-92.

CONDITIONS :

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, six months prior to its expiry.

1. Name & address of the building : AVB Adarsh Vidya Bhawan at F-277-278, Laxmi Nagar, Delhi-92.
2. Building is comprised of : Ground +2 upper floor
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC : F6/MS/DFS/School/2015/NDZ/2012 dt-06/11/15
6. Fire Safety direction letter No : Delhi Fire Service Act 2007 & Rules 2010
7. Date of Inspection : 04/12/18
8. Name of the Inspecting Officers: : ADO R.K. Yadav
9. Name of the designation of Officer
from the building side : Sh. Pankaj Verma (Manager)
10. Year of Construction : 2010
11. Applicant's letter No. : Nil dated 22/11/18


S. N	Minimum Standards on fire safety requirements as per	Requirement	Provided at Site	Remarks MR/NMR
1.	Access to building			
	Road width	6 m	5 m	MR old Accepted
	Gate width	N.A	N.A	N.A
	Width of internal road	N.A	N.A	N.A
2.	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	2 no.	2 no.	MR
	• Basement	N.A	N.A	N.A
	b. Width of Staircases			
	• Upper Floor	1.2 m	1.2 m each	MR old Accepted
	• Basement	N.A	N.A	N.A
	c. Protection of exits			
	• Fire check door	N.A	N.A	N.A
	• Pressurization	N.A	N.A	N.A
	d. No. of continuous staircases to terrace	2 no.	2 no.	MR
	e. Width of Corridor	1.5 m	1.7 m	MR
	f. Door Size	1 m	1 m	MR
3.	Compartmentation.			
	Fire check door	N.A	N.A	N.A
	Sealing of electrical shafts	N.A	N.A	N.A
	Fire rating of shaft door	N.A	N.A	N.A
	Water curtain	N.A	N.A	N.A
	Fire Dampers	N.A	N.A	N.A
4.	Smoke Management System.			
	Basement	N.A	N.A	N.A
	Upper floor	N.A	N.A	N.A
5.	Fire Extinguisher			
	Total numbers	10 no.	10 no.	MR
	Types	CO ₂ & ABC	Provided	MR
	ISI marking	ISI marked	Provided	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	01 no.	Provided	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A	N.A	N.A
	Location of main panel	N.A	N.A	N.A
	Location of repeater panel	N.A	N.A	N.A
	Alternate source of power	N.A	N.A	N.A
	Hooters	N.A	N.A	N.A
8	MOEFA	N.A	N.A	N.A
9	Public address System.	N.A	N.A	N.A
10	Automatic Sprinkler System.			
	Basement	N.A	N.A	N.A
	upper floor	N.A	N.A	N.A
	sprinkler above false ceiling	N.A	N.A	N.A
11	Internal Hydrants			
	size of riser/down-comer	N.A	N.A	N.A
	Number of hydrants per floor	N.A	N.A	N.A
	Hose Box	N.A	N.A	N.A
12	Yard Hydrants.			
	Total number of hydrants	N.A	N.A	N.A
	Hose Box	N.A	N.A	N.A
13	Pumping Arrangements.			
	• Ground Level	N.A	N.A	N.A
	➤ Discharge of main Pump	N.A	N.A	N.A
	➤ Head of Main Pump	N.A	N.A	N.A
	➤ Number of main pumps	N.A	N.A	N.A
	➤ Jockey pump out put	N.A	N.A	N.A
	➤ Jockey pump head	N.A	N.A	N.A
	➤ Standby pump out put	N.A	N.A	N.A
	➤ Standby pump Head	N.A	N.A	N.A
	➤ Auto Starting /Manual stopping	N.A	N.A	N.A
	➤ Pump House Access	N.A	N.A	N.A
	• Terrace Level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the Pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A	N.A	N.A
	Draw-off connection	N.A	N.A	N.A
	Fire service inlet	N.A	N.A	N.A
	Access to tank	N.A	N.A	N.A
	Overhead Tank capacity	10,000 liters	Provided	MR
15	Exit Signage.	Required	Provided	MR


16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A	N.A	N.A
	Pressurization of Lift lobby	N.A	N.A	N.A
	Communication in lift car	N.A	N.A	N.A
	Firemen's grounding switch	N.A	N.A	N.A
	Lift Signage	N.A	N.A	N.A
17	Standby power supply	N.A	N.A	N.A
18	Refuge Area.			
	Total area	N.A	N.A	N.A
	Location	N.A	N.A	N.A
19	Fire Control Room			
	Detector system panel	N.A	N.A	N.A
	Flow switch panel	N.A	N.A	N.A
	PA system panel	N.A	N.A	N.A
	Batter backup	N.A	N.A	N.A
	Building Floor Plans	N.A	N.A	N.A
20	Special Fire Protection systems for protection of special Risks, if any:	N.A	N.A	N.A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules. The FSC issued vide letter no. F6/MS/DFS/School/2015/NDZ/2012 dt-06/11/15 renewal under the rule 35 of the Delhi Fire Service Rules 2010 is recommended.



Signature of the Inspecting Officer
 Name :- R. K. Yadav
 Designation :- ADO (LN)

796/CPO/1003
 12/12/19/17/12
 D.O/ED
 8/12
 DYLF/NDZ


C.F.P.
 M.Scell
 FT/10
 12/12

Sir, FT letter is put up for signature pls

