

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI-110001**

No. F.6/DFS/MS/School/2018/SZ/ 2717

Dated: ...14/12/18

**FIRE SAFETY CERTIFICATE**

Certified that Balvantray Mehta Vidya Bhawan Anguridevi Shersingh Memorial Academy located at Block-E, G & H, Masjid Moth, Greater Kailash-II, New Delhi-110048 (ID-1925273), comprised of two interconnected blocks each ground plus three upper floors was issued NOC by this department vide letter No. F6/DFS/MS/2008/2339 dated 18-08-2008. The school premise was re-inspected by officer concern of this department on 06/09/2018 in the presence of Gp. Capt. (Retd.) S.C. Bahri (Director-cum-Manager) and observed that there has been addition in one portion of block-1 and one floor in block-2, as approved by this department. The school building **block-1** comprised of ground + 03 upper floors and **block-2** comprised of ground + 04 upper floors have complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Educational, Group-B**" (School) as above with effect from the date of issue of this certificate for period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued 14/12/18 at New Delhi by

14/12  
(Vipin Kental)  
Chief Fire Officer  
Ph: 011-23412225

Copy to: -

1. Director-cum-Manager, Balvantray Mehta Vidya Bhawan Anguridevi Shersingh Memorial Academy, Block-E,G & H, Masjid Moth, Greater Kailash-II, New Delhi-110048
2. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non- functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL- 2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT				
1	Name & Address of the Building	BALVANTRAY MEHTA VIDYA BHAWAN ANGURI DEVI SHERSINGH MEMORIAL ACADEMY, Block- E, G & H, Masjid Moth, Greater Kailash-II, New Delhi-48		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Block-1: G+3, Block-2: G+4 (Interconnected at all levels)		
4	Type of Case	Old case with addn. of 01 portion in Bk-1 & 01 floor in Bk-2		
5	Details of Previous NOC	F6/DFS/MS/2008/2339 dated 18-08-2008		
6	Fire Safety Directives Letter No	F6/DFS/MS/BP/2013/122 dated 07-01-2013		
7	Date of Inspection	06-09-2018		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Gp. Capt. SC Bahri (Retd.), (Director-cum-Manager)		
10	Year of construction	2003		
11	Applicant letter No.			
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	BBL / NBC Requirement	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>			
	• Road width	12 mtr	Provided	MR
	• Gate width	4.5m	Provided	MR
	• Width of internal road	6m	Provided as marked on plan	MR
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	Bk-1: GF to 3 <sup>rd</sup> Fl- 03 Nos Bk-2: GF to 2 <sup>nd</sup> Fl- 03 Nos and GF to 4 <sup>th</sup> Fl- 02 Nos	Provided	MR (old case)
	➤ Basement floor.	-NA-	-NA-	-NA-
	<b>b) Width of Staircase</b>			
	➤ Upper floors	1.5 mtr	Bk-1: GF to 3 <sup>rd</sup> Fl-1.43, 1.49 & 1.46m Bk-2: GF to 2 <sup>nd</sup> Fl- 1.57, 1.4m, 1.37m and GF to 4 <sup>th</sup> Fl-1.57m, 1.4m	MR (old case)
	➤ Basement floor	-NA-	-NA-	-NA-
	<b>c) Protection of exits</b>			
	➤ Fire check door	Reqd. in Block 2	Provided	MR
	➤ Pressurization	-NA-	-NA-	-NA-
	<b>d) No. of continuous staircase to terrace</b>	Bk-1: 3, Bk-2: 1	Bk-1: 3 nos., Bk-2: 1no.	MR (old case)
	<b>e) Width of corridor</b>	-NA-	-NA-	-NA-
	<b>f) Door size</b>	Required	1m	MR
3	<b>Compartmentation.</b>			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	<b>Smoke Management system.</b>			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	-NA-	-NA-
5.	<b>Fire Extinguishers.</b>			
	• Total numbers	Required	30 Nos	MR
	• Types	ABC/CO2/W.CO2	ABC & CO2	MR
	• ISI Marking	ISI mark	Provided	MR
6.	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	4 No & 5 No on SF	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR

7.	<b>Automatic fire detection &amp; alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooter's location</li> </ul>	-NA-	-NA-	-NA-
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	Required	Provided	MR
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper floors</li> <li>Sprinkler above false ceiling</li> </ul>	-NA-	-NA-	-NA-
11.	<b>Internal Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Size of Riser/Down-comer</li> <li>Number of Hydrant per floor</li> <li>Hose box.</li> </ul>	100 mm	Provided	MR
		04 Nos	Provided	MR
		05 Nos	Provided	MR
12.	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants.</li> <li>Hose box.</li> </ul>	-NA-	-NA-	-NA-
13.	<b>Pumping arrangements.</b>			
	<ul style="list-style-type: none"> <li><b>Ground Level</b> <ul style="list-style-type: none"> <li>Discharge of main pump.</li> <li>Head of main pump.</li> <li>Number of main pumps.</li> <li>Jockey Pump output.</li> <li>Jockey Pump head.</li> <li>Standby Pump output.</li> <li>Standby Pump head.</li> <li>Auto Starting/Manual Stopping.</li> <li>Pump house access.</li> </ul> </li> <li><b>Terrace Level</b> <ul style="list-style-type: none"> <li>Discharge of pump.</li> <li>Head of pump.</li> <li>Power supply.</li> <li>Auto starting of pump.</li> </ul> </li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		-NA-	NA	-NA-
		-NA-	NA	-NA-
		-NA-	NA	-NA-
		-NA-	NA	-NA-
		-NA-	NA	-NA-
		-NA-	NA	-NA-
		900 LPM	Provided	MR
		40m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	<b>Captive water storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity. <ul style="list-style-type: none"> <li>Draw-off connection.</li> <li>Fire Service Inlet.</li> <li>Access to tank.</li> </ul> </li> <li>Overhead tank capacity.</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		Required	Provided	MR
		Required	Provided	MR
		25,000 Ltr	Provided	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft.</li> <li>Pressurization of lift lobby.</li> <li>Communication in lift car.</li> <li>Fireman's switch.</li> <li>Lift signage.</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		Required	Provided	MR
		-NA-	-NA-	-NA-
17.	<b>Standby Power Supply</b>	Required	Provided	MR
18.	<b>Refuge Area</b>			
	<ul style="list-style-type: none"> <li>Total area</li> <li>Location</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

19.	<b>Fire Control Room.</b> <ul style="list-style-type: none"> <li>• Detector system panel.</li> <li>• Flow switch panel.</li> <li>• PA system panel.</li> <li>• Battery backup.</li> <li>• Building floor plan.</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	-NA-	-NA-	-NA-

The Fire protection systems provided in the building/ premises were test checked at random and found functional at the time of inspection. The shortcomings communicated by this department vide letter dated 13/06/2018 found complied.

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010

Accordingly DFA is put up for approval and signature please.

*Mehmood*  
11/9/18

Signature of the Inspecting Officer  
 Name: Mehmood  
 Design: ADO (SJ)

Balvantray Mehta Vidya Bhawan Anguridevi Shersingh Memorial Academy, Greater Kailash-II, New Delhi

DO (SD)

*Anilash*  
11/9/18

*dy. PSO*

*[Signature]*  
u/s

*CFO (SP)*

*if it meets the exit requirement, as per the directions issued by dept vide letter dt. 7.1.13 u/s 187g.*

*dy. PSO*

*[Signature]*  
19/9

*DO (SO)*

*Anilash*  
1.0

