

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI- 110001

No. F.6/DFS/MS/EH/2018/SZ/ 2699

Dated: 14/12/18

**FIRE SAFETY CERTIFICATE**

Certified that the Eating House in the name & style of M/s **Delhi Barbeque** located at Ground floor of A-Block, Khasra No-383/2/1, 384/1, 384/3, NH-8, Mahipalpur Extension, New Delhi-110037, comprised of basement, lower ground, upper ground & 03 upper floors. The restaurant running at upper ground floor only have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 19/07/2018 in the presence of Mr. Vijay Kumar (General Manager) and that the premises is fit for occupancy class "Assembly, Group-D" (Restaurant) with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Issued on 14/12/18 at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer  
Ph: 011-23412225

Copy to: -

1. The DHO (NGZ), South MCD, Public Health Department, Najafgarh, New Delhi-110043
2. Proprietor, M/s Delhi Barbeque at Ground Floor of A-63, Khasra No-383/1/2, , DLF South Square, Sarojini Nagar, New Delhi-110023

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT				
1	Name & Address of the Building	M/s Delhi Barbeque at Ground Floor, A-Block, Khasra No. 383/2/1, 384/1, 384/3, NH-8, Mahipalpur Extn, New Delhi-37		
2	Type of Occupancy	Assembly, "Group-D" (Eating House)		
3	Building Comprised of	Basement, Lower GF, Upper GF & 03 upper floors		
4	Type of Case	New		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	19-07-2018		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Mr. Vijay Kumar (General Manager)		
10	Year of construction	2009	Restt located at Upper GF in Taurus Hotel	
11	Applicant letter No.	Outdoor diary No. 9473 dated 03-07-2018		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	NBC / BBL requirements	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>	<b>F.6/DFS/MS/GH/SZ/2018/1287 Dated 04-06-2018</b>		
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Restt. within Taurus Hotel	As above	MR
			As above	-NA-
			As above	-NA-
2	<b>Number, width, type &amp; arrangement of exits.</b>	Provided & Maintained by Taurus Hotel		
	<b>a) Number of Staircase</b>	Provided & Maintained by Taurus Hotel		
	➤ Upper floors.	-NA-	As above	-NA-
	➤ Basement floor.	-NA-	As above	-NA-
	<b>b) Width of Staircase</b>	Provided & Maintained by Taurus Hotel		
	➤ Upper floors	-NA-	As above	-NA-
	➤ Basement floor	-NA-	As above	-NA-
	<b>c) Protection of exits</b>	Provided & Maintained by Taurus Hotel		
	➤ Fire check door	-NA-	As above	-NA-
	➤ Pressurization	-NA-	As above	-NA-
	<b>d) No. of continuous staircase to terrace</b>	-NA-	As above	-NA-
	<b>e) Width of corridor</b>	-NA-	As above	-NA-
	<b>f) Door size</b>	2 exits	2.02m & 1.77m	MR
3	<b>Compartmentation.</b>	Provided & Maintained by Taurus Hotel		
	• Fire check door.	-NA-	As above	-NA-
	• Sealing of electrical shafts.	-NA-	As above	-NA-
	• Fire rating of shaft door.	-NA-	As above	-NA-
	• Water curtain	-NA-	As above	-NA-
	• Fire dampers.	-NA-	As above	-NA-
4.	<b>Smoke Management system.</b>	Provided & Maintained by Taurus Hotel		
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors / Restt. Area	12 ACPH	Provided in kitchen	MR
5.	<b>Fire Extinguishers.</b>	Provided & Maintained by Taurus Hotel		
	• Total numbers	06 Nos	10 Nos	MR
	• Types	ABC / CO2	CO2 & ABC	MR
	• ISI Marking	ISI marked	Provided	MR
6.	<b>First Aid Hose Reels.</b>	Provided & Maintained by Taurus Hotel		
	• Total numbers on each floor.	One	Provided 02 Nos	MR
	• Length of hose-reel hose.	30 mtr	Provided	MR
	• Nozzle Diameter	5 mm	Provided	MR

M/s Delhi Barbeque at A-Block, Kh. No-383/2/1, 384/1, 384/3, NH-8, Mahipalpur Extn, New Delhi-37



7	<b>Automatic fire detection &amp; alarming system.</b>	Provided & Maintained by Taurus Hotel		
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooter's location</li> </ul>	-NA-	Smoke & Heat	-NA-
		-NA-	Lower GF	-NA-
		-NA-	-NA-	-NA-
		-NA-	Provided	-NA-
		-NA-	Provided	-NA-
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	-NA-	-NA-	-NA-
10.	<b>Automatic Sprinkler System</b>	Provided & Maintained by Taurus Hotel		
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper floors.</li> <li>Sprinkler above false ceiling</li> </ul>	-NA-	As above	-NA-
		-NA-	As above	-NA-
		-NA-	As above	-NA-
11.	<b>Internal Hydrants.</b>	Provided & Maintained by Taurus Hotel		
	<ul style="list-style-type: none"> <li>Size of Riser/Down-comer</li> <li>Number of Hydrant per floor</li> <li>Hose box.</li> </ul>	-NA-	As above	-NA-
		-NA-	As above	-NA-
		-NA-	As above	-NA-
12.	<b>Yard Hydrants.</b>	Provided & Maintained by Taurus Hotel		
	<ul style="list-style-type: none"> <li>Total number of hydrants.</li> <li>Hose box.</li> </ul>	-NA-	As above	-NA-
		-NA-	As above	-NA-
13.	<b>Pumping arrangements.</b>			
	<ul style="list-style-type: none"> <li><b>Ground Level</b></li> </ul>	Fire fighting system is common for entire building		
	<ul style="list-style-type: none"> <li>Discharge of main pump.</li> <li>Head of main pump.</li> <li>Number of main pumps.</li> <li>Jockey Pump output.</li> <li>Jockey Pump head.</li> <li>Standby Pump output.</li> <li>Standby Pump head.</li> <li>Auto Starting/Manual Stopping.</li> <li>Pump house access.</li> </ul>	1620 LPM	1620 LPM	MR
		60 mtr	60 mtr	MR
		02 Nos	02 Nos	MR
		180 LPM	180 LPM	MR
		60 mtr	60 mtr	MR
		1620 LPM	1620 LPM	MR
		60 mtr	60 mtr	MR
		Required	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> <li><b>Terrace Level</b></li> </ul>	Fire fighting system is common for entire building		
	<ul style="list-style-type: none"> <li>Discharge of pump.</li> <li>Head of pump.</li> <li>Power supply.</li> <li>Auto starting of pump.</li> </ul>	225 LPM	As above	MR
		40m	As above	MR
		Required	As above	MR
		Required	As above	MR
14.	<b>Captive water storage for fire fighting.</b>	Fire fighting system is common for entire building		
	<ul style="list-style-type: none"> <li>Underground tank capacity.</li> <li>Draw-off connection.</li> <li>Fire Service Inlet.</li> <li>Access to tank.</li> <li>Overhead tank capacity.</li> </ul>	-NA-	1,00,000 Ltr	MR
		-NA-	Provided	MR
		-NA-	Provided	MR
		-NA-	Provided	MR
		2,500 Ltr	10,000 Ltr	MR
		Required	Provided	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>	Provided & Maintained by Taurus Hotel		
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft.</li> <li>Pressurization of lift lobby.</li> <li>Communication in lift car.</li> <li>Fireman's switch.</li> <li>Lift signage.</li> </ul>	-NA-	As above	-NA-
		-NA-	As above	-NA-
		-NA-	As above	-NA-
		-NA-	As above	-NA-
		-NA-	As above	-NA-
17.	<b>Standby Power Supply</b>	Required	Provided	MR
18.	<b>Refuge Area</b>			
	<ul style="list-style-type: none"> <li>Total area</li> <li>Location</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

M/s Delhi Barbeque at A-Block, Kh. No-383/2/1, 384/1, 384/3, NH-8, Mahipalpur Extn, New Delhi-37

		Provided & Maintained by Taurus Hotel		
19.	<b>Fire Control Room.</b> <ul style="list-style-type: none"> <li>• Detector system panel.</li> <li>• Flow switch panel.</li> <li>• PA system panel.</li> <li>• Battery backup.</li> <li>• Building floor plan.</li> </ul>	-NA-	As above	-NA-
		-NA-	As above	-NA-
		-NA-	As above	-NA-
		-NA-	As above	-NA-
		-NA-	As above	-NA-
		-NA-	As above	-NA-
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	-NA-	As above	-NA-

The Fire protection systems provided in the building/ premises were test checked at random and found functional at the time of inspection. Keeping in view the substantial satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010

Accordingly DFA is put up for approval and signature please.

*Jamood*  
29/7/18  
Signature of the Inspecting Officer  
Name: Mehmood  
Design: ADO (SJ)

M/s Delhi Barbeque at ~~Upper~~ GF, A-63, Khasra No-383/1/2, NH-8, Mahipalpur Extn, New Delhi-37

DO (SD)

*Pl. clarify about the requirement of overhead/ Terrace pump requirement?*  
*Jamilash*  
25/7/18

*ADO (SJ)* Awarded Inspections note put up for Approval.  
for Submission  
*Jamood*  
31/7/18 ADO(SJ)

*DO (Sd/Sd)*

*Jamilash*  
31/7/18

*DO (Sd/Sd)*

*Jamood*  
11/8

*proposed*  
The khasra no for both shops doesn't match. Pl check again.  
*11/8*

*Cfo s/p*  
*DO (Sd/Sd)*  
*m-sell*

