

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/School/2018/SZ/ 2722

Dated: 17.12.18

FIRE SAFETY CERTIFICATE

Certified that the Govt Girls Senior Secondary School No-3 located at Sarojini Nagar, New Delhi-110023, comprised of ground plus two upper floors was issued FSC by this department vide letter No. F6/DFS/MS/School/2014/SZ/1349 dated 30/10/2014. The said premises was re-inspected by officer concerned of this department on 07/12/2018 in presence of Mrs. Anuradha Seth (HOS) and on the request of school management for grant of FSC only for ground and one upper floor, the school building comprised of **Ground & First Floor only** have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education circular no. F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education, Govt. of NCT of Delhi and that the school building is fit for occupancy class "Educational Building" Group-B, with effect from the date of issue of this certificate for a period of Three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 17/12/18 at New Delhi by


(Vipin Kental)
Chief Fire Officer
Ph: 011-23412225


Copy to: -

1. The HOS, Govt Girls Senior Secondary School No-3, Sarojini Nagar, New Delhi-110023
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.
7. This FSC is issued for Ground & First Floor only, 2nd Floor of the school building shall not be used for school activity.
8. The Principal of the school will ensure the sealing of third floor and way of exit is also available to students for terrace in emergency.

INSPECTION REPORT

1	Name & Address of the Building	Govt. Girls Senior Secondary School No-3, Sarojini Nagar, New Delhi-110023 (1719027)		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	G+02 upper floors but school HOS has requested for renewal of NOC upto G+01 upper floor only.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/2014/SZ/1349 Dated 30-10-2014		
6	Fire Safety Directives Letter No	F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011		
7	Date of Inspection	07/12/2018		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Mrs. Anuradha Seth (HOS)		
10	Year of construction	1962		
11	Applicant letter No.	Outdoor Diary No. 14885 dated 12/10/2018		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	DOE Circular Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Accessible	6 mtr	MR
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	Required	Two	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	1.5m / 0.75m	1.60m each	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	One	MR
	e) Width of corridor	-NA-	1.5 mtr	MR
	f) Door size	1 mtr	Provided	MR
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4	Smoke Management system.			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	-NA-	-NA-
5	Fire Extinguishers.			
	• Total numbers	14 Nos	31 Nos	MR
	• Types	ABC / CO2	CO2 & ABC	MR
	• ISI Marking	ISI mark	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	-NA-	Two	-NA-
	• Length of hose-reel hose.	-NA-	30 mtr	-NA-
	• Nozzle Diameter	-NA-	5 mm	-NA-

Govt. Girls Senior Secondary School No-3, Sarojini Nagar, New Delhi-110023

19	Fire Control Room.			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20	Special Fire Protection System for the Protection of special Risk, if any.			-NA-
<p>The Fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection. School management has requested for renewal of NOC only for ground plus one upper floor. Thus the shortcoming issued by the department vide letters dated 08/07/208 & 20/07/2018 may be deemed complied.</p> <p>In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the DOE circular, FSC issued vide letter No F6/DFS/MS/School/2014/SZ/1349 Dated 30/10/2014, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended up to 1st floor only.</p> <p>Accordingly DFA is put up for approval and signature please.</p>				
<p><i>[Signature]</i> Signature of the Inspecting Officer Name: Mehmood Design: ADO (SJ)</p>				

Govt. Girls Senior Secondary School No-3, Sarojini Nagar, New Delhi-110023

DO (SD) *Re. Speaks,*
Kanp
11/12

G. P. Singh
 Sir,
 HOS, GSSS No 3 Sarojini Nagar - 110023 is given a letter in which they asking only noc for G+2 floor (Second floor) will be selected not utilizing. as it is not required.

Submitted please
[Signature]
 14/12/18
 AMR-SSJ

DO (SD) on leave
ACFOCS2)
 Re Speaks

Spoken SNO-13 *[Signature]*
 is not required for G+2 floor. as