

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6 DFS/MS/CNG/2018/SZ/ 2700

Dated: 14/12/18

FIRE SAFETY CERTIFICATE

Certified that M/s Indrasprastha Gas Limited Retail Outlet (CNG Pump) at IGI Airport, New Delhi, comprised of Ground floor only was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/CNG/2015/SZ/346 dated 13.03.2015. The premises was re-inspected by officer concerned of this department on 04/12/2018 in presence of Mr. Pushpender (Manager) and found that said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Storage** (CNG Pump) 02 cascades at ground level, 02 compressor units and 03 dispensing units with effect from _____ for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 of Delhi Fire Service Rules, 2010 and subject to compliance of the conditions mentioned below.

Issued on _____ at New Delhi by


(Vipin Kental)
Chief Fire Officer
Ph: 011-23412225

Copy to: -

1. Sh. Alok Sharma, Chief General Manager (Fire & Safety), IGL Bhawan, Plot No-4, Community Centre, RK Puram, Sector-9, New Delhi-110022
2. The Addl. Comm. of Police (Lic.), First floor, P.S. Defence Colony, New Delhi.-110049

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	M/s Indraprastha Gas Ltd. Retail Outlet (CNG Pump) at IGI Airport, New Delhi-110037		
2	Type of Occupancy	Storage (CNG Pump), 02 Cascades, 02 Compressor units & 03 Dispensing units at ground floor.		
3	Building Comprised of	Ground floor only.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/CNG/2015/SZ/346 Dated 13-03-2015		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	04-12-2018		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Mr. Pushpender (Manager)		
10	Year of construction	2010		
11	Applicant letter No.	IGL/F&S/2018/15/87/02 dated 04-05-2018		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	9 mtr	Provided	MR
	• Gate width	6 mtr	Provided	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	-NA-	-NA-	-NA-
	➤ Basement.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	-NA-	-NA-	-NA-
	➤ Basement	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	-NA-	-NA-	-NA-
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1m	Provided	MR
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4	Smoke Management system.			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
5	Fire Extinguishers.			
	• Total numbers	Required	75kg-04, 10kg-20, 4.5kg-06, Total=30 Nos.	MR
	• Types	CO2 & DCP	DCP & CO2 type	MR
	• ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	-NA-	-NA-	-NA-
	• Length of hose-reel hose.	-NA-	-NA-	-NA-
	• Nozzle Diameter	-NA-	-NA-	-NA-

Indraprastha Gas Ltd Retail Outlet (CNG Pump) at IGI Airport, New Delhi-110037


7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	Gas & flame	Provided in compressors & portable with staff	MR
	<ul style="list-style-type: none"> Location of Main Panel 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Location of Repeater Panel 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Alternate source of power 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Hooter's location 	Required	Technician room	MR
8	MOEFA	-NA-	-NA-	-NA-
9	Public Address System	-NA-	-NA-	-NA-
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Upper floors 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	-NA-	-NA-	-NA-
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Number of Hydrant per floor 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Hose box. 	-NA-	-NA-	-NA-
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Hose box. 	-NA-	-NA-	-NA-
13	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main pump. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Head of main pump. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Number of main pumps. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Jockey Pump output. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Jockey Pump head. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Standby Pump output. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Standby Pump head. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual Stopping. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Pump house access. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Head of pump. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Power supply. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Auto starting of pump. 	-NA-	-NA-	-NA-
14	Captive water storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Draw-off connection. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Fire Service Inlet. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Access to tank. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Overhead tank capacity. 	-NA-	-NA-	-NA-
15	No Smoking Signage.	Required	Provided in Hindi & English	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Pressurization of lift lobby. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Communication in lift car. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Fireman's switch. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Lift signage. 	-NA-	-NA-	-NA-
17	Standby Power Supply	-NA-	Provided DG Set	-NA-
18	Refuge Area			
	<ul style="list-style-type: none"> Total area 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Location 	-NA-	-NA-	-NA-

N/

19	Fire Control Room.			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	Co2 flooding system connected through detectors provided in each compressor unit	-NA-

The fire protection system provided in the premise test checked at random and found functional at the time of inspection. Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/CNG/2015/SZ/346 dated 13.03.2015, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.


Accordingly DFA is put up for approval and signature please.


 Signature of the Inspecting Officer
 Name: Mehmood
 Design: ADO (SJ)


Indraprastha Gas Ltd Retail Outlet (CNG Pump) at IGI Airport, New Delhi-110037

DO (SD)


21/12/18


D.P. Singh (S2)





21/12

FTM

CFO S2


Miscell



10/11


257/CS/S2
11/12/18/14/12

A. G. T. Delhi

Put up for signature please


12/12/18
ADO (S2)


Miscell


14/12