

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 00

No.F6/DFS/MS/School/2018/NDZ/ 2720

Dated: 17/12/18

FIRE SAFETY CERTIFICATE

Certified that the **Rajkiya Sarvodaya Kanya Vidyalaya** at Kalyanvas, Delhi- 92, Comprised of A block ground plus two & B and C block ground plus one upper floors owned/occupied by Rajkiya Sarvodaya Kanya Vidyalaya was issued FSC vide letter No. F6/DFS/MS/School/2012/3249 dated 06/09/12 (G+1). The school building was re-inspected by the officer concerned of this department on 04/12/18 in the presence of Mrs.Indu Sethiya (H.O.S.) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular F16/Estate/CC/FireSafety/2011/3298 to 3398 dated 01/03/11 issued by Director of Education and the school building is fit for occupancy class "B" 'Educational Building' with effect from 17/12/18... for a period of **three** years, subject to conditions, printed overleaf.

Issued on.....17/12/18.....at New Delhi by

14/12

(Vipin Kental)
Chief Fire Officer

17/12/18

To,

The Principal,
Rajkiya Sarvodaya Kanya Vidyalaya ,
Kalyanvas, Delhi- 92.

Copy to:-

- 1 The Principal,
Rajkiya Sarvodaya Bal Vidyalaya ,
Kalyanvas, Delhi- 92.
2. The Joint Director of Education (Land & Estate)
Directorate of Education,
Lucknow Road, Delhi-54.

CONDITIONS :

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, six months prior to its expiry.

1. Name & address of the building : R.S.K.V. at Kalyanvas , Delhi-91.
2. Building is comprised of : A block G+2, B block G+1 upper floors
3. Type of Occupancy : Educational
4. Type of Case : ~~New Case~~ (Addition/Alteration)
5. Details of Previous NOC letter : F6/DFS/MS/School/2012/3249 dated 06/09/12 (G+1)
6. Fire Safety Circular No. : F.16/Estate/CC/FS/2011/3298 to 3398 dt-1.3.11
7. Date of Inspection : 04/12/18
8. Name of the Inspecting officers : ADO R.K. Yadav
9. Name and designation of Officer from the building side : Mrs.Indu Sethiya (H.O.S.)
10. Year of Construction : 1983 & 2011
11. Applicant's letter No : RSKV/KV/2018/836 Dated 19/11/18

No.	Minimum Standards on fire prevention and fire safety U/R33.	Circular Requirement	Provided at Site	Remarks
1	Access to building			
	• Road width	06 M	06 M	MR
	• Gate width	4.5 M	4.5 M	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor			
	A- Block G+2	2 Nos	2 Nos	MR
	B- Block G+1	2 Nos	2 Nos	MR
	C- Block G+1	1 No	1 No	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	Upper Floor			
	A- Block G+2	1.25 M	1.25 M each	MR
	B- Block G+1	1.5 M	1.5 M each	MR
	C- Block G+1	1.5 M	1.5 M	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	1 No	1 No	MR
	g. Width of Corridor	1.5 M	2.40 M	MR
	h. Door Size	1.0 M	1.0 M	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	14 Nos.	14 Nos.	MR
	• Types	ABC & Co2	ABC & Co2	MR
	• IS marking	ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	2 Nos	2 Nos	MR
	• Length of hose reel hose	30 M	30 M	MR
	• Nozzle diameter	5 MM	5 MM	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level	N/A	N/A	N/A
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 Ltrs	10,000 Ltrs	MR
15	Exit Signage.	Required	Provided	MR

12/13

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The FSC issued vide letter no. F6/DFS/MS/School/2012/3249 dated 06/09/12 (G+1) renew under the circular no. F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.11 is recommended.

R.K. Yadav
5/12/2018

Signature of the Inspecting Officer
Name : R.K. Yadav
Designation:- ADO (LN)

DO(ED)

[Signature]
12/12

DY. CAO/MD-7

[Signature]

FTM.

- C.F.D.

M.S cell

[Signature]
12/12

Sm, FT letter is put up for signature

800/CF/NP2
17/12

CFO(CND2)

M.S cell

[Signature]
14/12

[Signature]
13/12/2018