

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001  
Fax No. 011-23412593, Ph. 011-23412225

No. F6/DFS/MS/School/2018/SZ/ 2711

Dated: 19/12/18

**FIRE SAFETY CERTIFICATE**

Certified that the Sanwal Das Memorial School, Mahawar Nagar, Kotla Mubarakpur, New Delhi 110003 comprised of ground plus three upper floor only was issued FSC by this department vide letter No. F.6/DFS/MS/2014/SZ/1643 dated 23/12/2014. The said premises was re-inspected by officer concerned of this department on 04/12/2018 in presence of Mr. Gopal Koli (Head Clark) and found that school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education circular no. F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education, Govt. of NCT of Delhi and that the school building is fit for occupancy class "Educational Building" Group-B, with effect from the date of issue of this certificate for a period of Three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 19/12/18 at New Delhi by

V  
13/12  
(Vipin Kental)  
Chief Fire Officer  
Ph: 011-23412225  
JA

Copy to: -

1. The Principal, Sanwal Das Memorial School, Mahawar Nagar, Kotla Mubarakpur, New Delhi- 110003
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

|               |   |   |                                      |                                      |
|---------------|---|---|--------------------------------------|--------------------------------------|
| 1             | Name & Address of the Building  | Sanwal Das Memorial School, Mahawar Nagar, Kotla Mubarakpur, New Delhi 110003 |                                      |                                      |
| 2             | Type of Occupancy   | Educational, Group-B (School)   |                                      |                                      |
| 3             | Building Comprised of   | Ground + 03 upper floors.   |                                      |                                      |
| 4             | Type of Case  | Renewal   |                                      |                                      |
| 5             | Details of Previous NOC   | F6/DFS/MS/2014/SZ/1643 Dated 23/12/2014                                       |                                      |                                      |
| 6             | Fire Safety Directives Letter No  | F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011                |                                      |                                      |
| 7             | Date of Inspection  | 04/12/2018  |                                      |                                      |
| 8             | Name of the Inspecting Officers   | Mehmood, ADO (SJ)   |                                      |                                      |
| 9             | Name & Designation of Officers from the building side   | Sh. Gopal Koli (Head Cleark)  |                                      |                                      |
| 10            | Year of construction  | 2010  |                                      |                                      |
| 11            | Applicant letter No.  | SDMS/134/HOS-25 dated 17/11/2018  |                                      |                                      |
| <b>S. No.</b> | <b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>  | <b>As Per Old NOC</b>   | <b>Provided at Site</b>              | <b>Remarks MR/NMR</b>                |
| <b>1</b>      | <b>Access to Building.</b>  |   |                                      |                                      |
|               | <ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>  | 6 mtr<br>-NA-<br>-NA-   | Provided<br>-NA-<br>-NA-             | MR<br>-NA-<br>-NA-                   |
| <b>2</b>      | <b>Number, width, type &amp; arrangement of exits.</b>  |   |                                      |                                      |
|               | <b>a) Number of Staircase</b>   |   |                                      |                                      |
|               | ➤ Upper floors.   | Two   | Two                                  | MR                                   |
|               | ➤ Basement floor.   | -NA-  | -NA-                                 | -NA-                                 |
|               | <b>b) Width of Staircase</b>  |   |                                      |                                      |
|               | ➤ Upper floors  | 1.5 m/0.75m   | 1.10m & 1.05m                        | MR (Old Case)                        |
|               | ➤ Basement floor  | -NA-  | -NA-                                 | -NA-                                 |
|               | <b>c) Protection of exits</b>   |   |                                      |                                      |
|               | ➤ Fire check door   | -NA-  | -NA-                                 | -NA-                                 |
|               | ➤ Pressurization  | -NA-  | -NA-                                 | -NA-                                 |
|               | <b>d) No. of continuous staircase to terrace</b>  | -NA-  | -NA-                                 | -NA-                                 |
|               | <b>e) Width of corridor</b>   | 1.5m  | Provided                             | MR                                   |
|               | <b>f) Door size</b>   | 1m  | Provided                             | MR                                   |
| <b>3</b>      | <b>Compartmentation.</b>  |   |                                      |                                      |
|               | <ul style="list-style-type: none"> <li>• Fire check door.</li> <li>• Sealing of electrical shafts.</li> <li>• Fire rating of shaft door.</li> <li>• Water curtain</li> <li>• Fire dampers.</li> </ul> | -NA-<br>-NA-<br>-NA-<br>-NA-<br>-NA-  | -NA-<br>-NA-<br>-NA-<br>-NA-<br>-NA- | -NA-<br>-NA-<br>-NA-<br>-NA-<br>-NA- |
| <b>4.</b>     | <b>Smoke Management system.</b>   |   |                                      |                                      |
|               | <ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper floors</li> </ul>  | 30 ACPH<br>12 ACPH  | -NA-<br>-NA-                         | -NA-<br>-NA-                         |
| <b>5.</b>     | <b>Fire Extinguishers.</b>  |   |                                      |                                      |
|               | <ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• ISI Marking</li> </ul>   | 14 Nos<br>ABC / CO2<br>ISI marked   | 14 Nos<br>ABC & Co2<br>Provided      | MR<br>MR<br>MR                       |
| <b>6.</b>     | <b>First Aid Hose Reels.</b>  |   |                                      |                                      |
|               | <ul style="list-style-type: none"> <li>• Total numbers on each floor.</li> <li>• Length of hose-reel hose.</li> <li>• Nozzle Diameter</li> </ul>  | Two<br>30m<br>5mm   | Provided<br>Provided<br>Provided     | MR<br>MR<br>MR                       |





N/11

|     |   |      |  |      |
|-----|---|------|--|------|
| 18. | <b>Refuge Area</b>  |      |  |      |
|     | • Total area  | -NA- | -NA-   | -NA- |
|     | • Location  | -NA- | -NA-   | -NA- |
| 19. | <b>Fire Control Room.</b>   |      |  |      |
|     | • Detector system panel.  | -NA- | -NA-   | -NA- |
|     | • Flow switch panel.  | -NA- | -NA-   | -NA- |
|     | • PA system panel.  | -NA- | -NA-   | -NA- |
|     | • Battery backup.   | -NA- | -NA-   | -NA- |
|     | • Building floor plan.  | -NA- | -NA-   | -NA- |
| 20. | <b>Special Fire Protection System for the Protection of special Risk, if any.</b> | -NA- | ABC type fire extinguisher provided near electrical panel. | -NA- |

The Fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the DOE circular, FSC issued vide letter No F.6/DFS/MS/2014/SZ/1643 dated 23/12/2014 renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended

Accordingly DFA is put up for approval and signature please.

*Mehmood*  
5/12/18  
Signature of the Inspecting Officer  
Name: Mehmood  
Design: ADO (SJ)

DO (SD)

*Mehmood*  
7/12/18

*eroc821*

*eroc821*  
7/12



210/CF2/S2  
11/12/18/11/12

*eroc821*

A. G. T. Delhi put up for signature please

*eroc821*

Mscell FTM.  
11/12

Mscell

*Mehmood*  
12/12/18  
020157