

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

Fax No. 011-23412593, Ph. 011-23412225


No. F.6/DFS/MS/School/2018/SZ/ 2714

Dated: ...14/12/18

FIRE SAFETY CERTIFICATE

Certified that the St. Mary's Public School located at 530, Durga Vihar, Devli, New Delhi-110062, comprised of ground plus two upper floors only was issued FSC by this department vide letter No. F.6/MS/DFS/School/2016/SZ/118 dated 18/01/2016. The said premise was re-inspected by officer concerned of this department on 26/11/2018 in the presence of Mr. James K.C. (Principal) and observed that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "**Educational Building**" Group-B, with effect from the date of issue of this certificate for period of **Three years** in accordance with DOE circular subject to compliance of the conditions mentioned below.

Issued 14/12/18 at New Delhi by


(Vipin Kental)
Chief Fire Officer

Copy to: -

1. The Principal, St. Mary's Public School, 530, Durga Vihar, Devli, New Delhi-110062
2. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	St. Mary's Public School, 530, Durga Vihar, Devli, New Delhi-110062		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Ground plus Two Upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/MS/DFS/School/2016/SZ/118 dated 18/01/2016		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	26/11/2018		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Mr. James K C (Principal)		
10	Year of construction	2005		
11	Applicant letter No.	Nil dated Nil		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	As Per Old NOC	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	6 mtr	5.70 m	MR(Old Case)
	• Gate width	3.5m	3.5m	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase	02 No's	02No's	MR
	➤ Upper floors.	-NA-	-NA-	-NA-
	➤ Basement floor.			
	b) Width of Staircase			MR (Old Case)
	➤ Upper floors	1.50m	1.90m & 0.85m	
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			-NA-
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	01 No	Provided	MR
	e) Width of corridor	1.5m	Provided	MR
	f) Door size	1m	Provided	MR
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	-NA-	-NA-
5.	Fire Extinguishers.			
	• Total numbers	15 Nos	15 Nos	MR
	• Types	ABC / CO2	ABC & Co2	MR
	• ISI Marking	ISI marked.	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	01 nos	01 nos at each floor	MR
	• Length of hose-reel hose.	30m	30m	MR
	• Nozzle Diameter	5mm	5mm	MR

N18

18.	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-
19.	Fire Control Room.			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The Fire protection systems provided in the premises were checked / operated at random and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rule, FSC issued vide letter No. F.6/MS/DFS/School/2016/SZ/118 dated 18/01/2016, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

Mehmood
31/12/18
Signature of the Inspecting Officer
Name: Mehmood
Design: ADO (SJ)

DO (SD)
Anilash
4/12/18

dy. C.O. (S2)

268/CO(S2)
4/12/18

dy. C.O.
4/12



Chf (S2) *M. S. Cell* *4/6/12*

A. S. H. Jethi *Put up for Signature* *Meemad*
4/12/18

dy. C.O. (S2) *M. S. Cell* *4/12/18*