

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No.F.6/DFS/MS/WZ/2018/ 2743

Dated: 24/12/2018

FIRE SAFETY CERTIFICATE

Certified that the **North Delhi Public School** Located at, **BP- Block, Shalimar Bagh, Delhi – 110088**. comprised of **BL-1= Ground Floor & BL-2= Ground + 2 Upper Floor + Some Rooms at terrace are sealed by bricks** was issued FSC vide Letter No. F6/DFS/MS/09/841 Dated-24/03/2009. The premises was re inspected by the officer concerned of this department on 03/10/2018 in the presence of Mrs. Shivani Verma (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 262–362 Dated 17-01-2005 and that the premises is fit for occupancy class “Educational” Group B, with effect from 24/12/18 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on24.12.18... at New Delhi by.


(Atul Garg)
Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Principal, North Delhi Public School, BP- Block, Shalimar Bagh, Delhi – 110088.
2. Directorate of Education Old Secretariat Delhi – 110054.
3. The Commissioner, Civil line Zone, North MCD,,Rajpura Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. **Rooms at terrace shall be kept closed / sealed as seen during the inspection.**
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: **North Delhi Public School** Located at, **BP- Block, Shalimar Bagh, Delhi – 110088.**
2. Type of Occupanc : Educational (BL-1= Ground Floor & BL-2= Ground + 2 Upper Floor + **Some Rooms at terrace are sealed by bricks**)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/09/841 Dated-24/03/2009
5. Fire Safety directives Letter No. : Cr.No.262-362 dated 17-01-05
6. Date of inspection : 03-10-2018
7. Name of the Inspecting Officer : Udaivir Singh ADO (WP)
8. Name and designation of Officer
from the building side : Mrs. Shivani Verma (Principal)
9. Year of Construction : 1996
10. Applicant's letter No. : JMPS/18-09-10 Dated-11/09/18

No. of Students=1096
No. of class rooms=51
Plot area=4046.25sqm
Covered area=1343.55sqm

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No.262-362 dated 17-01-05	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	8m Provided	MR
	• Gate width	Accessible	5.4 m Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2 Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5m	119cm & 122cm	MR(Old Case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	1mtr	Varies from 91cm to 1m	MR(Old Case)

Ag

3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	10 nos.	10 Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	01	01 Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down-comer	100 m.m	Provided	MR
	• Number of hydrants per floor	1	Provided	MR
	• Hose Box	4	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA

[Handwritten signature]

13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	Provided 180 LPM	NA
		40 mtrs.	40 mtrs.	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 lpm & 220 lpm	450 lpm & 220 lpm	MR
		40Mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	Provided	NA
		NA	NA	NA
		5,000Ltrs	5,000 ltrs Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA
		NA	NA	NA
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

31/01/2017

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/09/841 Dated-24/03/2009 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

NA
24/11/2018

Signature of the Inspecting Officer

Name *Udai Vir Singh*

Designation *IA/DO/WP*

Signature of the Inspecting Officer

Name

Designation

Noted

16/11/18

27/11/18

24/10/18

27/11/18

Ask them to remove the
Rays on room or submit the
fresh logs

28/11/18

Ans/WP

Spokane

28/11/18

Ans/WP

Jan

Sir FY letter is put up
ple.

20
19/12/18