

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2018/SZ/ 15

Dated:02/01/19

FIRE SAFETY CERTIFICATE

Certified that the Nursery School Building located at NS-10, Pocket-L, Sarita Vihar, New Delhi-110076, comprised of ground and first floor only, owned/occupied by Dream Land Society was granted No Objection Certificate by this department vide letter No. F6/MS/DFS/2005/1778 dated 29/08/2005. The said school building was re-inspected by the officer concerned of this department on 30/11/2018 in presence of Sh. V. Garg (Proprietor) and observed addition/alteration in the existing school building. The school building now comprise of basement, ground plus three upper floors have complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Educational Building" (Group-B) as above with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the condition under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 02/01/19 at New Delhi by


(Vipin Kental)
Chief Fire Officer
Ph. 011-23412225


Copy to: -


1. Auth. Signatory, Dream Land Society, NS-10, Pkt-L, Sarita Vihar, New Delhi-110076
2. Dy. Director (Education), South MCD, Jal Vihar, Lajpat Nagar-IV, New Delhi-110024

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL- 2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.


INSPECTION REPORT				
1	Name & Address of the Building	Nursery School at NS-10, Pocket-L, Sarita Vihar, New Delhi-110076 (Dreamland Society)		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Basement, Ground + 3 upper floors		
4	Type of Case	Renewal & Addition / Alteration		
5	Details of Previous NOC	F6/MS/DFS/2005/1778 Dated 29/08/2005 for G+1		
6	Fire Safety Directives Letter No.	Nil		
7	Date of Inspection	30-11-2018		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Sh. V. Garg (Proprietor)		
10	Year of construction	2018		
11	Applicant letter No.	Outdoor diary No. 14872 dated 12/10/2018		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	UBBL/NBC-2016 Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	6 mtr	9 mtr	MR
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 Nos	Provided	MR
	➤ Basement floor.	02 Nos	Provided	MR
	b) Width of Staircase			
	➤ Upper floors	1.5 mtr	1.50m each	MR
	➤ Basement floor	1.5 mtr	1.50m each	MR
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	One	Provided	MR
	e) Width of corridor	1.5m	Provided	MR
	f) Door size	1.2m	Provided	MR
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4	Smoke Management system.			
	• Basement	30 ACPH	Exhaust fan provided	MR
	• Upper floors	12 ACPH	Natural Ventilation	MR
5	Fire Extinguishers.			
	• Total numbers	10 Nos	20 Nos	MR
	• Types	ABC / CO2	ABC & CO2	MR
	• ISI Marking	ISI mark	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30 mtr	Provided	MR
	• Nozzle Diameter	5 mm	Provided	MR


Nursery School at NS-10, Pocket-L, Sarita Vihar, New Delhi-110076

19	Fire Control Room.			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20	Special Fire Protection System for the Protection of special Risk, if any.			-NA-
<p>The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection. Keeping in view of the substantial satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010.</p> <p>Accordingly DFA is put up for approval and signature please.</p> <p style="text-align: right;">  Signature of the Inspecting Officer Name: Mehmood Design: ADO (SJ) </p>				

Nursery School at NS-10, Pocket-L, Sarita Vihar, New Delhi-110076

DO (SD)


18/12/18




18/12


C.F.O. 24

M.Scell

F.T.O.


28/12

A G.T. Delhi being up for signature please


21/1/19
ADO (SJ)

C.F.O. C.F.P.

M.Scell


2/1



284/CFO/S2
2-1-19