

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

NO F 6/DFS/MS/EH/2018/NDZ/ 09

Dated:-02/01/2019

FIRE SAFETY CERTIFICATE

Certified that the M/S Privee Novele XO, Delhi (A Unit of MJ Bizacrafts LLP), located at Kanishka Shopping Arcade, at Ground floor, Hotel Sangri- las- Eros, 19 Ashoka Road, New Delhi. The Restaurant is running on ground floor, The restaurant was issued FSC by This Department vide letter F.6/DFS/MS/EH/2015/NDZ/2132 dated 03/12/2015 owned/occupied by the department M/S Privee Novele XO, Delhi (A Unit of MJ Bizacrafts LLP), was re- inspected by the officer concerned of this department on 21-12-2018 in the presence of Sh. Virender singh (Fire Officer) and found that the department have complied with the fire prevention and fire safety requirement in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy of class Assembly Group- D with effect from 02/01/19 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 mentioned below.

Issued on-----02/01/19-----at New Delhi

(Vipin Kantal)
Chief Fire Officer
Delhi Fire Service

o/c [Signature]

Copy to:-1. M/S Privee Novele XO, Delhi (A Unit of MJ Bizacrafts LLP), located at Kanishka Shopping Arcade, at Ground floor, Hotel Sangri- las- Eros, 19 Ashoka Road, New Delhi.

2. The Medical Officer of Health, NDMC, Palika Kendra, New Delhi.

Following fire safety directives may be adhered to :-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. The means of escape shall be kept unobstructed/unlocked & remain available for speedy evacuation of occupants in case of an emergency.
of smooth and speedy safe evacuation of occupants in case of emergency
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
rendering non functional of fire safety measures, management shall be responsible.
4. Any deviation with regard to construction, electric shall be verified by the concerned building sanctioning authority.
5. The trained fire fighting staff should be available around the clock.
6. This fire safety certificate may not be treated in any case for regularizations of unauthorized construction if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi fire service 2010. The form is available on www.dfs.delhigovt.nic.in.
8. The owner / occupier shall apply for renewal of this fire safety certificated to the director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
9. The owner / occupier shall apply for renewal of this fire safety certificated to the director in Form 'the

2. Type of Occupancy : Group-D Assembly Building, Gr. + 2 Restaurant at Ground Floor
 3. Type of Case : Renewal
 4. Details of previous NOC : F6/DFS/MS/EH/2015/NDZ/2132 Dated 03/12/2015.
 5. Fire Safety directives Letter No. : F6/DFS/MS/EH/2015/NDZ/2132 Dated 03/12/2015.
 6. Date of inspection : 21-12-18
 7. Name of the Inspecting Officer : Sunil chawdhary (DY.C.F.O)
 8. Name and designation of Officer from the building side : Sh. Virender Singh (Fire Officer)
 9. Year of Construction : Old Heritage.
 10. Applicant's letter No. : No. 5717/Addl. CP/Lic./EH(DA-IV), New Delhi Dated 26/11/2018.

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirement as per	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	09 mtr	09 mtr	MR
	• Gate width	05 mtr	05 mtr	MR
	• Width of internal road	6 mtr	06 mtr	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	03 Nos.	03 Nos.	MR
	• Basements	05 Nos..	05 Nos.	MR
	b. Width of staircases			
	• Upper floors	N/R	N/R	N/R
	• Basements	N/R	N/R	N/R
	c. Protection of exits			
	• Fire check door	Required	Provide	MR
	• Pressurization	Required	Provide	MR
	d. No of continuous staircase to terrace	02	02	MR
	e. Width Of Corridor	1.5 mtr	1.5 mtr	MR
	f. Door Size	2 mtr X 4	4 Nos 2 mtr.& 1 Nos. 1.20 mtr	MR
3.	Compartmentation			
	• Fire check door	Required	Provide	MR
	• Sealing of electrical shafts	Required	Provide	MR
	• Fire Rating of shaft door	Required	Provide	MR
	• Water Curtain	Required	Provide	MR
	• Fire Dampers	Required	Provide	MR
4	Smoke managements System			
	• Basements	30 a/ c per	mechanical	MR

	<ul style="list-style-type: none"> Total numbers Types IS marking 	20 nos.	25 nos.	MR
		ABC & Co ₂ Fome	ABC & Co ₂ Fome	MR
		ISI marked	Provided	MR
6	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 36 m 5 mm	01 36 m 5 mm	MR MR MR
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Required	Provided	MR
		Required	Provided	MR
		Zone Wise	Zone Wise	MR
		Required	Provided	MR
		Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler			
	Basements	Required	Provided	MR
	<ul style="list-style-type: none"> Upper Floor Sprinkler above false ceiling 	Required	Provided	MR
		Required	Provided	MR
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	150 m.m 02 each Floor 02 each Floor	150 m.m 02 each Floor 02 each Floor	MR MR MR
12	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	02 02	02 02	MR MR
13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping 	Not Required	Provided 2850 LPM	MR
		Not Required	Provided 60 mtr.	MR
		Not Required	Provided 02	MR
		2850 LPM	Provided 2850 LPM	MR
		Not Required	Provided 30 mtr.	MR
		180 LPM	Provided 180 LPM	MR
		60 mtr.	60 mtr.	MR
		Required	Provided	MR

	<ul style="list-style-type: none"> • Terrace level • Discharge of pump • Head of the pump • Power supply • Auto starting of pump 	450 Lpm	Provided	MR
		40 ltr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive water Storage for fire fighting			
	• Under ground tank capacity	Not Required	2,50,000 Ltr.	MR
	• Draw of connection	Required	Provided	MR
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead Tank capacity	20,000 Ltrs.	20,000 Ltrs.	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	• Pressurization of Lift Shaft	Required	Provided	MR
	• Pressurization of lift lobby	Required	Provided	MR
	• Communication in lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	• Total area	N.A.	N.A.	N.A
	• Location	N.A.	N.A.	N.A
19	Fire control room			
	• Detector system panel	Required	Provided	MR
	• Flow Switch Panel	Required	Provided	MR
	• PA System Panel	Required	Provided	MR
	• Batter backup	Required	Provided	MR
	• Building Floor Plans	N.A.	N.A.	N.A
20	Special Fire Protection Systems for Protection of special Risks, if any: CO ₂ , ABC			

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/2015 NDZ/2132 Dated 03/12/2015 may be renewed under rule 35 of the Delhi Fire Service rules 2010 as recommended.

C.F.O.

[Signature]