

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001



NO. F6/DFS/MS/School/2018/SZ/13

Dated: 2/1/19

FIRE SAFETY CERTIFICATE

Certified that the R C S D Primary Public School, at Gali No.3, Sadh Nagar, Palam Colony, New Delhi-110045, Comprised of ground plus one upper floor, having two blocks was issued Fire Safety Certificate by this department vide letter No.F6/DFS/MS/School/2015/SZ/1637 dated 10.9.2015. The said school building was re-inspected by the officer concerned of this department on 26.12.2018 in the presence of Smt. Usha Sharma (Principal) and found that the premises have deemed with the fire prevention and fire safety requirements in accordance with Directorate of Education GNCT of Delhi Circular No. DOE 1.3.2011 and that the building/premises is fit for occupancy of class B "Educational Building" with effect from 2/1/19 for a period of **three years** subject to compliance of the conditions , printed overleaf.

Issued on2/1/19..... at New Delhi by


2/1
o/c (Vipin Kental)
Chief Fire Officer


Copy to:-

- 1 Dy. Director (Education) GNCT of Delhi, Old Secretariat, Delhi-110054.
- 2 Principal, R C S D Primary Public School, at Gali No.3, Sadh Nagar, Palam Colony, New Delhi-110045.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

1	Name & address of the building	R C S D Primary Public School ,Gali No.3, Sadh Nagar, Palam New Delhi-110045.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal (G+1)		
4	Details of previous NOC	F6/DFS/MS/School/2015/SZ/637 dated 10.09.2015		
5	Fire safety directives letter No	Directorate Of Education Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011.		
6	Date of inspection	26.12.2018		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Mrs. Usha Sharma (Head Mistress)		
9	Year of construction	Old Block Before 2010 & New Block 2015		
10	Applicant's letter No.	Nil dated 27.11.2018	Ground plus one upper floor, having Two Blocks Namely old & New Block	
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement/ DOE CIR. Dated 1.3.2011	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	6 Mtrs.	Provided	MR
	2) Gate width	4.5 Mtrs.	Direct accessible from road	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	3 Nos.	Provided	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.50 Mtrs., if less than 1.50 Mtr. additional staircase of .75 Mtr. is required	Old Block 1.35 Mtrs. (2 Nos.) & New Block 1.50 Mtrs.	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	1.50 Mtrs.	1.75 to 2.50 Mtrs.	MR
	f. Door size	1 Mtr.	Provided	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement		N/A	N/A
	upper floors	N/A	N/A	N/A
5	Fire Extinguishers			
	total numbers	1 CO2 OR ABC for every 300 Sq. Mtrs.	8 Nos.	MR
	Types		ABC	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

419

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: provided near electrical panel	ABC Fire Extinguisher MR		

The fire protection system provided in the building were checked and found functional at the time of inspection.
 Keeping in view compliance of the minimum standards on fire prevention and fire safety requirements as per DOE Cir. Dated 1.3.2011, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/SZ/1637 dated 10.09.2015 is recommended.

S.P. Bhardwaj
 26/12/18
 S.P. Bhardwaj
 ADO Dwarka

DO/SW

293/DOCSW
 dt. 26/12/18

[Signature]
 26/12/18

DCFO (S2) - CL

CF0 (S2) m-scell FT for
 28/12

FT for signature pen

[Signature]
 21/11/19

220/CF0/SE
 2-7-19

CF0 S2 m-scell 2/11