

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/2018/SZ/ 37

Dated: 7/11/19

FIRE SAFETY CERTIFICATE

Certified that M/s "Shaurya" CRPF Officers Institute at Plot No-08, Institutional Area, C-9, Vasant Kunj, New Delhi-110070, comprised of basement, ground plus one upper floor, owned/occupied by Central Reserve Police Force, Govt. of India was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/2016/SZ/588 dated 08/04/2016. The premises was re-inspected by the officer concerned of this department on 10/12/2018 in the presence of Sh. Raj Kumar (S.I./CRPF) and observed that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Assembly" as above with effect from 7/11/19.... for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Issued on 7/11/19 at New Delhi by


(Vipin Kental)
Chief Fire Officer
Ph: 011-23412225


Copy to: -

1. Officer-in-Charge, "Shaurya" CRPF Officer's Institute, Plot No-8, Institutional Area, C-9, Vasant Kunj, New Delhi-110070

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of DFS Rules, 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT

1	Name & Address of the Building	"SHAURYA" CRPF Officers Institute, Plot No-08, Institutional Area, C-9, Vasant Kunj, New Delhi-70		
2	Type of Occupancy	Assembly Building		
3	Building Comprised of	B+G+01 (Block-1 only), Block-2 not constructed		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/2016/SZ/558 dated 08-04-2016		
6	Fire Safety Directives Letter No	F6/MS/DFS/BP/2003/1524 dated 09-07-2003		
7	Date of Inspection	10-12-2018		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Sh. Raj Kumar, (S.I./CRPF)		
10	Year of construction	2008		
11	Applicant letter No.	Outdoor Diary No. 15566 dated 26-10-2018		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	06 mtr	12 mtr	MR
	• Gate width	5 mtr	Provided	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	03 + 01 ramp	Provided	MR
	➤ Basement floor.	04 + 01 ramp	Provided	MR
	b) Width of Staircase			
	➤ Upper floors	1.5m	1.5m each & 1.2m ramp	MR
	➤ Basement floor	1.5m / 1.25m	1.5m (03), 1.25m (01) & 5.9m ramp	MR
	c) Protection of exits			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	One	Provided	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1.5m	1.5m (04no. in auditorium)	MR
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	30 ACPH	Exhaust fan provided	MR
	• Upper floors	12 ACPH	Exhaust fan provided	MR
5.	Fire Extinguishers.			
	• Total numbers	30 Nos	34 Nos	MR
	• Types	ABC / CO2	W.CO2 & CO2	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	02 Nos	Provided	MR
	• Length of hose-reel hose.	30 mtr	Provided	MR
	• Nozzle Diameter	5 mm	Provided	MR

"SHAURYA" CRPF Officers Institute at Plot No-08, Institutional Area, C-9, Vasant Kunj, New Delhi

7	Automatic fire detection & alarming system.			
	• Type of detectors	Required	Heat, Smoke & Beam	MR
	• Location of Main Panel	Required	Ground floor	MR
	• Location of Repeater Panel	Required	Fire Control Room	-NA-
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	Required	On each floor	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper floors	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants.			
	• Size of Riser/Down-comer	150 mm	Provided	MR
	• Number of Hydrant per floor	02 Nos	Provided	MR
	• Hose box.	02 Nos	Provided	MR
12.	Yard Hydrants.			
	• Total number of hydrants.	Required	Provided	MR
	• Hose box.	Required	Provided	MR
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	2850 LPM	2280 & 2250 LPM	MR
	➤ Head of main pump.	70m	70m	MR
	➤ Number of main pumps.	01 No	02 Nos	MR
	➤ Jockey Pump output.	180 LPM	180 LPM	MR
	➤ Jockey Pump head.	70m	70m	MR
	➤ Standby Pump output.	2850 LPM	2850 LPM	-NA-
	➤ Standby Pump head.	70m	70m	-NA-
	➤ Auto Starting / Manual Stopping.	Required	Provided	MR
	➤ Pump house access.	Required	Provided	MR
	• Terrace Level			
	➤ Discharge of pump.	-NA-	-NA-	-NA-
	➤ Head of pump.	-NA-	-NA-	-NA-
	➤ Power supply.	-NA-	-NA-	-NA-
	➤ Auto starting of pump.	-NA-	-NA-	-NA-
14.	Captive water storage for fire fighting.			
	• Underground tank capacity.	2,00,000 Ltr	Provided	MR
	➤ Draw-off connection.	Required	Provided	MR
	➤ Fire Service Inlet.	Required	Provided	MR
	➤ Access to tank.	Required	Provided	MR
	• Overhead tank capacity.	10,000 Ltr	20,000 Ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	Required	Provided	MR
	• Fireman's switch.	Required	Provided	MR
	• Lift signage.	Required	Provided	MR
17.	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-

19.	Fire Control Room.	Required	Provided	MR
		-NA-	-NA-	-NA-
		Required	Provided	MR
		Required	Provided	MR
		-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.			-NA-
<p>The fire protection system provided in the building/ premises were tested, checked at random and found functional at the time of inspection. Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/2016/SZ/558 dated 08/04/2016, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.</p> <p>Accordingly DFA is put up for approval and signature please.</p>				
				<p style="text-align: right;"><i>(Signature)</i> 13/12/18</p> <p style="text-align: right;">Signature of the Inspecting Officer Name: Mehmood Design: ADO (SJ)</p>

"SHAURYA" CRPF Officers Institute at Plot No-08, Institutional Area, C-9, Vasant Kunj, New Delhi

DO (SD)

(Signature)
18/12/18

(Signature)
27/1/19

(Signature)
19/12

CFOS/ST

M.S cell

R.T.M.

(Signature)
28/12

M. S. Cell letter for signature please

(Signature)
21/1/19
M.S cell

(Signature)
27/1/19

M.S cell *(Signature)*



27/1/19
CFOS/ST