


FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F-6/DFS/MS/WZ/SCHOOL/2019/ 174

Dated: 24/01/2019

Certified that the **ST. Rosier Public School CD-4, Shalimar Bagh Delhi-110088** comprised of Ground + 03 Upper Floors was issued FSC vide Letter No. **F6/DFS/MS/2005/2704 Dated 28-12-2005**. The premises was re inspected by the officer concerned of this department on 16/01/2019 in the presence of **Sh. Sudhir (Employee)** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 3298 – 3398 Dated 17-01-2011 and that the premises is fit for occupancy class "Educational" Group B with effect from 24/1/19 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions Issued on at New Delhi by.
Fire Service Rules, 2010.

Issued on24.1.19.... at New Delhi by.


(Atul Garg)
Chief Fire Officer,
Delhi Fire Service

Copy to:

1. The Principal, ST. Rosier Public School CD-4, Shalimar Bagh Delhi-110088
2. Directorate Of Education Old Secretariat Delhi – 110054

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: **ST. Rosier Public School CD-4,
Shalimar Bagh Delhi-110088.**
2. Type of Occupancy : **Educational (Ground + 3 Upper Floor)**
3. Type of Case : **Renewal**
4. Details of previous NOC : **F6/DFS/MS/2005/2704 Dated 28-12-2005**
5. Fire Safety directives Letter No. : **Cr.No.3298-3398 dated 1-3-11**
6. Date of inspection : **16/01/2019**
7. Name of the Inspecting Officer : **Udaivir Singh, ADO (WP)**
8. Name and designation of Officer

from the building side : **Sh. Sudhir (Employee)**
9. Year of Construction : **2005**
10. Applicant's letter No. : **STRPS/2018/FIRESTN/NOC/555 Dated-21/12/18**

No. of Students=960
No. of class rooms=24
Plot area=1.5063 Acre
Covered area=3049m²

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No.3298-3398 dated 1-3-11	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> Accessible Accessible NA 	<ul style="list-style-type: none"> Provided Provided NA 	<ul style="list-style-type: none"> MR MR NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	2x1.5mtrs	Provided 1x1.6m&1x1.7m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	1.5m	177cm Provided	MR
	f. Door Size	100cm	120cm	MR(old case)

