

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/

School/2018/02/182

Dated: *25/1/2019*

FIRE SAFETY CERTIFICATE

Certified that the Govt. Co-ed Sr. Secondary school (**New Building**) (ID-1617004), Nangloi Delhi- 110041 comprised of Ground + Three upper floors only owned / occupied by Govt. Co-ed Sr. Secondary school was inspected by the officer concerned of this department on 17.01.2019 in presence of Mr. Rishi Raj (Vice Principal) and found that the owner/occupier have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class Educational (Group B) with effect from *25/1/19* for a period of 3 (Three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on *25/1/19* at New Delhi by.


(ATUL GARG)

CHIEF FIRE OFFICER

Copy to :-

1. Principal, Govt. Co-ed Sr. Secondary school (**New Building**) (ID-1617004), Nangloi Delhi- 110041
2. Assistant Engineer (E), Sub-div.-I, Edu. Maint., Div. M1-1, PWD, I T I Campus Pusa, New Delhi-110012.
3. Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-110054.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

1. Name & address of the building: Govt. Co-ed Sr. Secondary school (**New Building**)
(ID-1617004), Kavita Colony, Nangloi Delhi- 110041.

2. Type of Occupancy : Educational *C New Building* G+3

3. Type of Case : New
4. Details of previous NOC : Nil

Covered Area Each Floor-215m ²
Ground + Three Upper Floors

5. Fire Safety directives Letter No. : NBC (Part-IV)

6. Date of inspection : 17/01/2019

7. Name of the Inspecting Officer : A.D.O. (Jwala Puri)

8. Name and designation of Officer
from the building side : Mr. Rishi Raj (Vice Principal)

9. Year of Construction : 2016-17

10. Applicant's letter No. : 54(SPS School)/PWD EDU.Maint. Div. / M-1/2018-19/46
dated 24/12/2018

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE Circ. Dt. 01/03/2011 / NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	6 mtr	MR
	• Gate width	4.5 mtr	4.5 mtr	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.50 Mtr. & 1.35 mtr	1.80 mtr x 1 1.50 mtr x 1	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	1	1	MR
	e. Width Of Corridor	1.50 Mtr.	1.80 Mtr	MR
	f. Door Size	1.00 Mtr.	1.10 Mtr x 2	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	8	10	M/R
	• Types	ISI marked ABC/CO ₂	Provided	MR
	• IS marking	Required	Provided	M/R

6.	First - Aid Hose Reels			
	• Total numbers on each floor	1	1	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	N/A	N/A	
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM x 2	MR
	➤ Head of the pump	40 MH	40 MH	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA

X/10

	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:- General requirements for schools as per Director of Education circular dated 01/03/2011.

1. Escape route:- Clear
2. LPG cylinders in laboratories :- Nil
3. Electric wiring:- Conduit Wiring MCB and ELCB.....
Electric circuit:- MCB Provided
4. Electric meter board / switch board panel.:-Not Under the staircase
5. Basement use as per BBL 1983 :- N/A
6. Emergency telephone no. board :- Displayed
7. Generator set :- NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

D.O. (West)

[Handwritten signature]
20/1/19

[Handwritten signature]
24/1/19

CFO West

[Handwritten signature]
24/1/19

28/1/19

FDP

but up for sign

[Handwritten signature]
21/1/19

Signature of the Inspecting Officer
Name : A.K. Jaiswal
Designation : A.D.O. (Jwala Puri)