

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No.F6/DFS/MS/WZ/2019/ 177

Dated: 24 /01/2019

FIRE SAFETY CERTIFICATE

Certified that the **Government Sarvodaya Bal Vidyalaya,(Old Building)** Located at **(Without Auditorium) Ramesh Nagar, New Delhi – 110015**, comprised of Ground Floor & Ground+ 01 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/WZ/SCHOOL/2015/1514 Dated-19/08/15 The premises was re inspected by the officer concerned of this department on 02-01-2019 in the presence of Mr. Rajener Kumar Tyagi (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 3298-3398 dated 01-03-2011 and that the premises is fit for occupancy class "Educational" Group B with effect from 24/1/19 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...24/1/19..... at New Delhi by.


(Atul Garg)
Chief Fire Officer,
Delhi Fire Service

Copy to: 1. The Principal, Govt. Sarvodaya Bal Vidyalaya,(Old Building) Ramesh Nagar, New Delhi –15.

2. Director of Education, Old Secretariat, Delhi-110054

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

1. Name & address of the building: **Govt. Sarvodaya Bal Vidyalaya, Located at (Old Building) (Without Auditorium) Ramesh Nagar, New Delhi – 110015.**
2. Type of Occupancy: Educational (Ground Floors & Ground + 01 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/WZ/SCHOOL/2015/1514 Dated- 19/08/15
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
6. Date of inspection : 02-01-2019
7. Name of the Inspecting Officer : Udai vir Singh, ADO (WP)
8. Name and designation of Officer
from the building side : Mr. Rajener Kumar Tyagi (Principal)
9. Year of Construction : (G F Only – 1950), (G+1) 2013
10. Applicant's letter No. : GSBV/RN/2018/1014 Dated 29/10/18

No. of Students=1700
No. of class rooms=44
Plot area=6400 sqm
Covered area=4400sqm

S No	Minimum standards on fire prevention and fire safety U/R	DOE 3298-3398 dated 01-03-2011	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	<ul style="list-style-type: none"> Accessible Accessible NA 	<ul style="list-style-type: none"> 6m Provided 4.5 Provided NA 	<ul style="list-style-type: none"> MR MR NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper floors Basements 	<ul style="list-style-type: none"> 1 NA 	<ul style="list-style-type: none"> 2 Provided NA 	<ul style="list-style-type: none"> MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper floors Basements 	<ul style="list-style-type: none"> 1.5 m NA 	<ul style="list-style-type: none"> 2X1.55m NA 	<ul style="list-style-type: none"> MR NA
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	1.5m	172 cm	MR
	f. Door Size	2X1m	Double Door Provided	MR
	g. Hall(With Stage)	4X1.5m	4x153cm	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> Basements Upper floors 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	<ul style="list-style-type: none"> 17 nos. ABC & CO₂ 	<ul style="list-style-type: none"> 20 Provided ABC & CO₂ Provided 	<ul style="list-style-type: none"> MR MR

6.	First – Aid Hose Reels			
	• Total numbers on each floor (For Auditorium)	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter			
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/WZ/SCHOOL/2015/1514 Dated-19/08/15 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Not:- The shortcoming communicated for auditorium are still not completed. FSC is recommended except auditorium, to the

Signature of the Inspecting Officer

Name *Uday Vir Singh*
Designation *ADD/CP*

Signature of the Inspecting Officer

Name
Designation

D. P. W. Z. 15/11/19
D. P. W. Z. 15/11/19
CFD. W. Z. 15/11/19

*End NOC plus info
shud build is G+3.
pls clarify*

14/11/19

D. P. W. Z. 17/11/19
ADD/CP

Sir it is a another block (old block) comprised of ground plus one upper floor premises.