

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001

No. F.6/DFS/MS/GH/SZ/2019/ 186

Dated: 25.11.19

**FIRE SAFETY CERTIFICATE**

Certified that Guest House in the name & style of M/s **Hotel Purple Orchid** situated at Khasra No-325/2, Rangpuri, New Delhi-110037, comprised of Basement (parking), Ground floor (Rec., office & 03 guest rooms), 1<sup>st</sup> Floor (09 guest rooms), 2<sup>nd</sup> Floor (09 guest rooms) and 3<sup>rd</sup> Floor (09 guest rooms), total 30 guest rooms have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 11/01/2019 in the presence of Mr. Jagbir Singh (Proprietor) and that the premises is fit for occupancy class "**Residential, Group-A**" (Lodging or Rooming House) as above with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Issued 25/11/19 at New Delhi by

*VK*  
*25/11*  
(Vipin Kental)  
Chief Fire Officer  
Ph. 011-23412225  
*OK*

Copy to: -

1. DHO, South MCD, Public Health Department, Najafgarh Zone, Dhansa Stand, Najafgarh, New Delhi-110043
2. Proprietor M/s Hotel Purple Orchid at Khasra No-325/2, Rangpuri, New Delhi-110037

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

