GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO.F6/DFS/MS/School/2019/SZ/ 194 Dated: 25/1/19

FIRE SAFETY CERTIFICATE

Certified that the M.D.H International School (An institute of Mahashya Chuni Lal Charitable Trust) at Plot no.3, Sector-6 Dwarka New Delhi-110075, comprised of ground plus three upper floors was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2015/2123 dated 2.12.2015. The premises was re-inspected by the officer concerned of this department on 10.1.2019 in presence of Smt. Nandini Bidalia (Principal) & Sh. R K Wadhera (Manager) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class B "Educational building" with effect from.....25/1/19... for a period of **three** years subject to compliance of the conditions printed overleaf.

Issued on .....25/1/19..... at New Delhi by

25/1
Vipin Kental
D/C Chief Fire Officer

Copy to:-

1. The Dy.Director, (Education), G.N.C.T of Delhi, Old Secretariat, New Delhi-54.
2. Manager, M.D.H International School (An institute of Mahashya Chuni Lal Charitable Trust) at Plot no.3, Sector-6 Dwarka, New Delhi-110075.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	M.D.H International School at Plot No.3, Pocket-2, Sector-6, Dwarka, New Delhi-110075.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal (Ground Plus Three upper Floors)		
4	Details of previous NOC	F6/DFS/MS/School/2015/SZ/2123 dated 2.12.2015		
5	Fire safety directives letter No	F6/DFS/MS/BP/2002/1659 dated 19.09.2002		
6	Date of inspection	10.01.2019		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Mrs. Nandini Bidalia (Principal) & Sh. R K Wadhera (Manager)		
9	Year of construction	Before 2002		
10	Applicant's letter No.	Nil dated 24.12.2018	Ground plus three upper Floor	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	DOE letter dated 1.3.2011/ letter dated 2.12.2015	Provided at site	Remarks MR / NMR
1	**Access to building**			
	1) Road width	6 Mtrs.	Provided	MR
	2) Gate width	4.5 Mtrs.	Provided	MR
	3) Width of internal road	N/A	N/A	N/A
2	**Number, width Type & arrangement of exits**			
	a. Number of staircases			
	1. Upper floors	Two	Two	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.50 Mtrs.	Provided	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	2 Nos.	Provided	MR
	e. Width of corridor	1.50 Mtrs.	1.80 Mtrs.	MR
	f. Door size	1 Mtr.	Provided	MR
3	**Compartmentation.**			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	**Smoke Management system.**			
	basement	N/A 12 a/c charge	N/A	N/A
	upper floors		Natural Vent.	MR
5	**Fire Extinguishers**			
	total numbers	17 Nos.	Provided	MR
	Types	CO_2 & ABC	Provided	MR
	ISI marking	ISI Marked	Provided	MR

6	**First-Aid Hose Reels.**			
	total numbers on each floor	One	Provided	MR
	Length of Hose reel hose	30 m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
7	**Automatic fire detection and alarming system**			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	**MOEFA**	N/A	N/A	N/A
9	**Public Address System.**	N/A	N/A	N/A
10	**Automatic Sprinkler System.**			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	**Internal Hydrants**			
	Size of riser/down-corner	N/A	100 mm	MR
	Number of Hydrants per floor	N/A	One	MR
	hose Box	N/A	Provided	MR
12	**Yard Hydrants.**			
	total number of hydrants	N/A	1 No.	MR
	hose box	N/A	N/A	N/A
13	**Pumping arrangements**			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b.Head of main pump	N/A	N/A	N/A
	c.Number of main pumps	N/A	N/A	N/A
	d.jockey pump out put	N/A	N/A	N/A
	e.jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g.Stanby Pump head	N/A	N/A	N/A
	h.Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2.Terrace level			
	a. Discharge of pump	900 LPM	Provided	MR
	b. head of the pump	30 Mtrs.	Provided	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	**Captive water storage for fire fighting**			
	1. Underground tank capacity	N/A	50,000 Ltrs.	MR
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	MR
	c.Access to tank	N/A	N/A	N/A
	Over head tank Capacity	10000 Ltrs.	Provided	MR
15	**Exit Signage.**	Required	Provided	MR
16	**Provision of lifts.**			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

17	**Standby power supply**	N/A	N/A	N/A
18	**Refuge Area.**	Not Required		
	total area	N/A	N/A	N/A
	location	N/A	N/A	N/A
19	**Fire control room**			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	**Special Fire Protection systems for protection of special risks:** CO_2 Fire extinguisher provided near electric Panel.			

The fire protection systems provided in the building were checked and found funtional at the time of insoection.
Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety requirement under the rules, renewal of fire safety certificate issued vide letter no. F6/DFS/MS/2015/SZ/2123 dated 02.12.2015 is recommended.

Accordingly DFA is put up for approval and signature please.

11/1/19
S.P. Bhardwaj
ADO (Dwarka)

11/DO(SW)
11.01.2019

11/1/2019

DCFO (S2)

377/CFO/S2
18/1/19/25/1

DELHI FIRE SERVICE
Date 21-1-19
Diary No. 572
Dy. Chief Fire Office (SZ)

16/1

CFO S/4 m.scell 17/1

FT for Signature please.

21/1/19

CFO S2/

M.scell 25/1