

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/WZ/2019/ 176

Dated: 24/01/2019

FIRE SAFETY CERTIFICATE

Certified that the **M. C. D. Primary School**, Located at **Saraswati Garden New Delhi-110015** comprised of Ground + 1 Upper Floor owned/occupied by **M. C. D. Primary School**, have complied with the fire prevention and fire safety requirements in accordance DOE Circular 3298 – 3398 Dated 01-03-2011 and verified by the officer concerned of Fire Service on 16/01/2019 in the presence of Ms. Anita (Incharge) and that the building/premises is fit for occupancy "Educational" Group B (**Except maltactivity Hall**) with effect from24/1/19.... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ..24/1/19..... at New Delhi by.

(Atul Garg)
Chief Fire Officer,
Delhi Fire Service

Copy to:-

1. M. C. D. Primary School, Saraswati Garden New Delhi-110015
2. Directorate Of Education Old Secretariat Delhi – 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: **M. C. D. Primary School**, Located at **Saraswati Garden New Delhi-110015**
2. Type of Occupancy : Educational (Ground + 1 Upper Floor)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
6. Date of inspection :16/01/2019
7. Name of the Inspecting Officer :Udai vir singh, ADO (WP)
8. Name and designation of Officer
from the building side :Ms. Anita (Incharge)
9. Year of Construction : 2002
10. Applicant's letter No. :Nil dated-10/12/2018

No. of Students=551
 No. of class rooms=17
 Plot area=3486.84m²
 Covered area=788.95m²

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No.3298-3398 dated 1-3-11	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1	2 Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	150cm	1x178cm, 1x152cm	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	1 mtr	1m Provided	MR

