

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F.6/DFS/MS/School/NDZ/2019 / 216

Dated: 28/1/19

FIRE SAFETY CERTIFICATE

Certified that the M/s Sandhya Sr. Sec. Public School, C-182/12, Gali (Akhare Wali) No.-1, Chauhan Banger, Delhi- 110094, comprised of Ground plus two upper floors owned / occupied by Sandhya Sr. Sec. Public School was issued FSC vide letter No. F.6/DFS/MS/School/2015/NDZ/1846 Dated 14/10/15. The school building was re-inspected by the officer concerned of this department in presence of Deepak Kumar, Manager of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular Letter No. F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/11 issued by Director of Education and observed that the school building is fit for occupancy class "B" 'Educational Building' with effect from 28/1/19 ... for a period three year, subject to conditions printed overleaf.

Issued on..... 28/1/19 at New Delhi by


(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

To,
The Principal,
M/s Sandhya Sr. Sec. Public School,
C-182/12, Gali (Akhare Wali) No.-1,
Chauhan Banger, Delhi -110094.

Copy to:-
The Joint Director of Education
(Land & Estate),
Directorate of Education, Lucknow Road, Delhi -110054.

- Conditions -

- 1 All the means of escape shall be kept free of all type of obstruction all the time.
- 2 All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"

