

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/SCHOOL/2019/NDZ/ 240

Dated: 30/1/19

FIRE SAFETY CERTIFICATE

Certified that M/s Samrat Inn Guest house running at first & second floor only of the building comprised of basement, ground plus three upper floors (basement lying vacant, ground floor shop, first floor reception plus 06 guest rooms, second floor 07 guest rooms & third floor residence of owner) at 181, Saini Enclave, Karkardooma, Delhi-110092, owned/occupied by M/s Samrat Inn was issued FSC vide letter No. F6/DFS/MS/GH/2015/NDZ/2264 dated 31/12/2015. The building was re-inspected by the officer concerned of this department in the presence of Mr. Prateek Gupta, Owner of the guest house and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rules 33 of the Delhi Fire Service Rules, 2010 and observed that the building is fit for occupancy class "A" 'Residential Building' for first and second floor (13 rooms) with effect from 30/1/19 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 30/1/19 at New Delhi by

(Vipin Kental)
Chief Fire Officer

O/c
V

To,

The Chairman
M/s Samrat Inn Guest House,
181, Saini Enclave, Karkardooma,
Delhi-110092

Copy:-

The Addl. Commissioner of Police
Licensing Unit, 1st floor,
Police Station Defence Colony,
New Delhi

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. All comments/directions of the Licensing Department shall always be permitted and flowed.
7. Basement shall be used as per BBL.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
9. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

