

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2019/ CNG/ 305

Dated 6/2/19

FIRE SAFETY CERTIFICATE

Certified that the **CNG Filling Station(IGL) Rohini(Mega)** located at **Sector-21, Rohini, Delhi-110086** comprised of **Single Story Building** owned/ occupied by **Indraprastha Gas Limited** was issued fire safety certificate by this department vide letter no. **F6./DFS/MS/2016/CNG/187 dated 29.01.2016**. The premises was re-inspected by the officers concerned of this department on 21.01.2019 in the presence of **Sh. Jahangir Anshari, Manager** and found that the building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and the building/ premise is fit for occupancy "**CNG Filling Station Group 'J'**" with effect from6/2/19..... for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

Issued on6/2/19..... at New Delhi by

(Atul Garg)

Chief Fire Officer

Ph:-011-23414250

Copy to :-

1. Chief General Manager (Project), Indraprastha Gas Limited, IGL Bhawan, Plot no-4, Community Centre, R.K. Puram, Sec-09, New Delhi-110022.

INSPECTION REPORT

1. Name & address of the building :CNG Filling Station(IGL) Rohini Mega at Sector-21, Rohini, Delhi-86.
2. Type of Occupancy : CNG Filling station **Group 'J'**
3. Type of Case :Renewal
4. Details of previous NOC :F6/DFS/MS/2016/CNG/187 Dated:29.01.2016
5. Fire Safety directives letter No :--
6. Date of inspection :21/01/2019
7. Name of the Inspecting Officers :ADO (RN)
8. Name and designation of officers
from the building side : Mr. Jahangir Anshari, Manager
9. Year of Construction : --
10. Applicant's letter No. : IGL/F&S/2018/15/42 dated 11.12.2018

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	08m	30m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.0m	1.0m	MR

