

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No.F.6/DFS/MS/2019/WZ/ 298

Dated: 6 / 2 / 2019

**FIRE SAFETY CERTIFICATE**

Certified that the D.A.V. Centenary Public School, at Paschim Enclave, Rohtak Road, Delhi-87, comprised of Ground + Three Upper Floors owned / occupied by D.A.V. Centenary Public School, has already been issued Fire Safety Certificate Vide letter No. F6/DFS/MS/2015/WZ/927 dated 05/06/2015. The premises was re-inspected by the officer concerned of Fire Service on 25.01.2019 in the presence of Sh. Rakesh Kaila (Sr. Assistant) & Sh. Souu Kumar (Bldg. Supervisor) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Directorate of Education, Circular No. 262-362 dated 17.01.2005 and that the building / premises is fit for occupancy class-B Educational with effect from 6 / 2 / 2019 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 6/2/19 at New Delhi by.

  
(ATUL GARG)  
CHIEF FIRE OFFICER

Copy to :-

1. The Principal, D.A.V. Centenary Public School, Paschim Enclave, Rohtak Road, Delhi-110087.
2. Dy. Director of Education, West-B, Block-G, Zone-17, Vikas Puri, New Delhi-110018.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. There shall not be more than 45 students in class rooms in any case.
8. Fourth Floor shall not be used for any purpose and kept sealed all the time as found during inspection and the undertaking given by management vide their letter No. DAV/MN/PR/2015-16/053 dated 27/4/2015.

