**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**
**NEW DELHI-110001**
Fax No. 011-23412593, Ph. 011-23412225

No. F.6/DFS/MS/School/2019/SZ/ 281 Dated: 4.1.19

## FIRE SAFETY CERTIFICATE

Certified that the Rajeshwari Karuna School located at D–95, Sanjay Colony, Bhati Mine, New Delhi-110074, comprised of ground floor only owned/occupied by Aashalata Victoria Wilkinson Memorial C. Trust was issued FSC by this department vide letter No. F.6/DFS/MS/School/2015/SZ/10 dated 01/01/2016. The said premises was re-inspected by officer concerned of this department on 11/01/2019 in the presence of Mr. Anil Wilkinson (Manager) and found that school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education circular no F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education, Govt. of NCT of Delhi and that the school building is fit for occupancy class "Educational Building" Group–B with effect from the date of issue of this certificate for period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued 4/1/19 at New Delhi by

**(Vipin Kental)**
**Chief Fire Officer**

Copy to: -

1. The Principal, Rajeshwari Karuna School located at D–95, Sanjay Colony, Bhati Mines, New Delhi-110074
2. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

### Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

N/4

| INSPECTION REPORT | | | | |
|---|---|---|---|---|
| 1 | Name & Address of the Building | Rajeshwari Karuna School,D-95,Sanjay Colony, Bhati Mine, New Delhi-110074 | | |
| 2 | Type of Occupancy | Educational, Group–B (School) | | |
| 3 | Building Comprised of | Ground floor only | | |
| 4 | Type of Case | Renewal | | |
| 5 | Details of Previous NOC | F6/DFS/MS/School/2015/SZ/10 dated 01/0/2016 | | |
| 6 | Fire Safety Directives Letter No | F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 | | |
| 7 | Date of Inspection | 11/01/2019 | | |
| 8 | Name of the Inspecting Officers | Mehmood, ADO (SJ) | | |
| 9 | Name & Designation of Officers from the building side | Mr. Anil (Manager) | | |
| 10 | Year of construction | 2011 | | |
| 11 | Applicant letter No. | RKS/AVWMCT/2018/071 dated 06/12/2018 | | |
| **S. No.** | **Minimum standards on Fire Prevention and Fire Safety U/R 33** | **As Per Old Noc** | **Provided at Site** | **Remarks MR/NMR** |
| **1** | **Access to Building.** | | | |
| | • Road width | 6m | 5.70 m | MR ( Old Case) |
| | • Gate width | -NA- | -NA- | -NA- |
| | • Width of internal road | -NA- | -NA- | -NA- |
| **2** | **Number, width, type & arrangement of exits.** | | | |
| | **a) Number of Staircase** | | | |
| | ➢ Upper floors. | -NA- | -NA- | -NA- |
| | ➢ Basement floor. | -NA- | -NA- | -NA- |
| | **b) Width of Staircase** | | | |
| | ➢ Upper floors | -NA- | -NA- | -NA- |
| | ➢ Basement floor | -NA- | -NA- | -NA- |
| | **c) Protection of exits** | | | |
| | ➢ Fire check door | -NA- | -NA- | -NA- |
| | ➢ Pressurization | -NA- | -NA- | -NA- |
| | **d) No. of continuous staircase to terrace** | -NA- | -NA- | -NA- |
| | **e) Width of corridor** | -NA- | -NA- | -NA- |
| | **f) Door size** | 1m | Provided | MR |
| **3** | **Compartmentation.** | | | |
| | • Fire check door. | -NA- | -NA- | -NA- |
| | • Sealing of electrical shafts. | -NA- | -NA- | -NA- |
| | • Fire rating of shaft door. | -NA- | -NA- | -NA- |
| | • Water curtain | -NA- | -NA- | -NA- |
| | • Fire dampers. | -NA- | -NA- | -NA- |
| **4.** | **Smoke Management system.** | | | |
| | • Basement | 30 ACPH | -NA- | -NA- |
| | • Upper floors | 12 ACPH | -NA- | -NA- |
| **5.** | **Fire Extinguishers.** | | | |
| | • Total numbers | 06 Nos | 06 Nos | MR |
| | • Types | ABC / CO2 | ABC & Co2 | MR |
| | • ISI Marking | ISI marked | Provided | MR |
| **6.** | **First Aid Hose Reels.** | | | |
| | • Total numbers on each floor. | -NA- | -NA- | -NA- |
| | • Length of hose-reel hose. | -NA- | -NA- | -NA- |
| | • Nozzle Diameter | -NA- | -NA- | -NA- |

| | | | | |
|---|---|---|---|---|
| 7. | **Automatic fire detection & alarming system.** | | | |
| | • Type of detectors | -NA- | -NA- | -NA- |
| | • Location of Main Panel | -NA- | -NA- | -NA- |
| | • Location of Repeater Panel | -NA- | -NA- | -NA- |
| | • Alternate source of power | -NA- | -NA- | -NA- |
| | • Hooter's location | -NA- | -NA- | -NA- |
| 8. | **MOEFA** | -NA- | -NA- | -NA- |
| 9. | **Public Address System** | -NA- | -NA- | -NA- |
| 10. | **Automatic Sprinkler System** | | | |
| | • Basement | -NA- | -NA- | -NA- |
| | • Upper floors | -NA- | -NA- | -NA- |
| | • Sprinkler above false ceiling | -NA- | -NA- | -NA- |
| 11. | **Internal Hydrants.** | | | |
| | • Size of Riser/Down-comer | -NA- | -NA- | -NA- |
| | • Number of Hydrant per floor | -NA- | -NA- | -NA- |
| | • Hose box. | -NA- | -NA- | -NA- |
| 12. | **Yard Hydrants.** | | | |
| | • Total number of hydrants. | -NA- | -NA- | -NA- |
| | • Hose box. | -NA- | -NA- | -NA- |
| 13. | **Pumping arrangements.** | | | |
| | • **Ground Level** | | | |
| | ➢ Discharge of main pump. | -NA- | -NA- | -NA- |
| | ➢ Head of main pump. | -NA- | -NA- | -NA- |
| | ➢ Number of main pumps. | -NA- | -NA- | -NA- |
| | ➢ Jockey Pump output. | -NA- | -NA- | -NA- |
| | ➢ Jockey Pump head. | -NA- | -NA- | -NA- |
| | ➢ Standby Pump output. | -NA- | -NA- | -NA- |
| | ➢ Standby Pump head. | -NA- | -NA- | -NA- |
| | ➢ Auto Starting / Manual Stopping. | -NA- | -NA- | -NA- |
| | ➢ Pump house access. | -NA- | -NA- | -NA- |
| | • **Terrace Level** | | | |
| | ➢ Discharge of pump. | -NA- | -NA- | -NA- |
| | ➢ Head of pump. | -NA- | -NA- | -NA- |
| | ➢ Power supply. | -NA- | -NA- | -NA- |
| | ➢ Auto starting of pump. | -NA- | -NA- | -NA- |
| 14. | **Captive water storage for fire fighting.** | | | |
| | • Underground tank capacity. | -NA- | -NA- | -NA- |
| | ➢ Draw-off connection. | -NA- | -NA- | -NA- |
| | ➢ Fire Service Inlet. | -NA- | -NA- | -NA- |
| | ➢ Access to tank. | -NA- | -NA- | -NA- |
| | • Overhead tank capacity. | -NA- | -NA- | -NA- |
| 15. | **Exit Signage.** | Required | Provided | MR |
| 16. | **Provision of Lifts.** | | | |
| | • Pressurization of lift shaft. | -NA- | -NA- | -NA- |
| | • Pressurization of lift lobby. | -NA- | -NA- | -NA- |
| | • Communication in lift car. | -NA- | -NA- | -NA- |
| | • Fireman's switch. | -NA- | -NA- | -NA- |
| | • Lift signage. | -NA- | -NA- | -NA- |
| 17. | **Standby Power Supply** | -NA- | -NA- | -NA- |
| 18. | **Refuge Area** | | | |
| | • Total area | -NA- | -NA- | -NA- |
| | • Location | -NA- | -NA- | -NA- |

N/6

| | | | | |
|---|---|---|---|---|
| **19.** | **Fire Control Room.** | | | |
| | • Detector system panel. | -NA- | -NA- | -NA- |
| | • Flow switch panel. | -NA- | -NA- | -NA- |
| | • PA system panel. | -NA- | -NA- | -NA- |
| | • Battery backup. | -NA- | -NA- | -NA- |
| | • Building floor plan. | -NA- | -NA- | -NA- |
| **20.** | **Special Fire Protection System for the Protection of special Risk, if any.** | -NA- | -NA- | -NA- |

The Fire protection systems provided in the premises were checked / operated at random and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the DOE circular, FSC issued vide letter No. F.6/DFS/MS/School/2015/SZ/10 dated 01/01/2016 renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

16/1/19

Signature of the Inspecting Officer
Name: Mehmood
Design: ADO (SJ)

DELHI FIRE SERVICE Dy. Chief Fire Office (SZ) Date Diary No.

DO (SD)

18/1/19

Dy. CFO (SZ)

DELHI FIRE SERVICE Dy. Chief Fire Office (SZ) Date 21-1-19 Diary No. 981

21/1

FTA.

CFO (SZ) M.Scell 30/1

405/CFO/SZ
31/1/19/1/2

A. 6-7 letter Pending for Signature Please

31/1/19
ADO (SJ)

CFO (SZ) M.Scell 1/2