

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI- 110001



No. F6/DFS/MS/School/2019/SZ/ 301

Dated: 6/2/19

**FIRE SAFETY CERTIFICATE**

Certified that the **Savitri Public School** located at G-314, Sangam Vihar, New Delhi, comprised of basement, ground plus two upper floors only was issued FSC by this department vide letter No. F6/DFS/MS/School/2015/SZ/17 dated 04/01/2016. The school premises was re-inspected by the officer concerned of this department on 25/01/2019 in presence of Mr. Vikas Negi (Admin) and observed addition of third floor in the existing school building. The school building now comprised of basement, ground plus three upper floors have complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Educational Building, Group-B**" as above with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the condition under rule 38 of the Delhi Fire Service Rules, 2010

Issued on 6/2/19 at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer  
Ph. 011-23412225  


Copy to: -

1. Principal, Savitri Public School at G-314, Sangam Vihar, New Delhi-110080
2. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

