

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F-6/DFS/MS/Banq/2018/ 2742

Dated: 24/12/2018

FIRE SAFETY CERTIFICATE

Certified that the M/S Pushp Aleela Banquet (A unit of Pushp Food & Beverages) Located at , A-4, Wazir Pur Industrial Area, Delhi-110052, in a building comprised of Basement + Ground Floor + Two Upper Floors owned/ occupied by M/s Pushp Aleela Banquet have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of this department on 30-10-2018 in the presence of Sh. Gurmeet Singh (Owner) and found that the said building that the premises is fit for occupancy class " Assembly" Group D (Ground plus upper two floors Floor Only) with effect from 24/12/18 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on24.12.18.... at New Delhi by.


(Atul Garg)
Chief Fire Officer
Delhi Fire Service

Copy to: 1. M/s Pushp Aleela Banquet (A unit of Pushp Food & Beverages), A-4, Wazir Pur Industrial Area, Delhi-1100522.
2. The Dy Health Officer, A-1 Block, Keshav puram Zone, Public Health Department, Keshav Puram, Delhi.

Following fire safety directives must be adhered to:-

1. **The FSC is valid to run the banquet hall at Ground plus two upper floor only**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. **Basement shall be used as strictly per BBL 1983..**
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
10. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: **Pushp Aleela Banquet (A unit of Pushp Food & Beverages)** Located at , **A-4, Wazir Pur Industrial Area, Delhi-110052**
2. Type of Occupancy : Banquet, (Assembly) 2 Basement +Ground + First & Second Floor Only
3. Type of Case :New
4. Details of previous NOC ; Nil
5. Fire Safety directives Letter No. :F-6/DFS/MS//2018/3574 Dated -20/08/2018
6. Date of inspection . 19-11-2018
7. Name of the Inspecting Officer : DO/W & ADO (WP)
8. Name and designation of Officer
a. from the building side : Sh.Harish Asrani (Partner)
9. Year of Construction : 2010-11
10. Applicant's letter No. : Nil Dated – 18/10/2018

S N o	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 m	Provided	MR
	• Gate width	6 m	Provided	MR
	• Width of internal road	NA	On Road	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2 Provided	MR
	• Basements	2	Provided	MR
	b. Width of staircases			
	• Upper floors	2x2m	2x2 m & 1x1.6 to 2.1m(Up to FF)	MR
	• Basements	2x2m	2x2m & Ramp-575cm	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	2m	Provided	MR
	f. Door Size	2x1.5m	GF=1x139cm,1x214cm & 2x245cm FF=1x125cm,2x200cm & 1x142cm SF=1x183cm,1x200 cm & 1x203cm	MR

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	Separate AC units are provided for individual floor	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	Required	Provided	MR
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	ABC, CO2 & WCO2 ISI marked	Provided	MR
	<ul style="list-style-type: none"> • Types 		Provided	MR
	<ul style="list-style-type: none"> • IS marking 		Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	2	Provided	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 m	Provided	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	Smoke & Heat	Provided	MR
	<ul style="list-style-type: none"> • Location of Main Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> • Location of Repeater Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> • Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> • Hooters' Location 	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements 	Required	Provided	MR
	<ul style="list-style-type: none"> • Upper Floor 	NA	Provided	NA
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down- comer 	150 mm	Provided	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	2	Provided	MR
	<ul style="list-style-type: none"> • Hose Box 	Required	Provided	MR
12	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	NR	Provided	NR
	<ul style="list-style-type: none"> • Hose Box 	NR	Provided	NR

13	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 			
		2280 lpm	Provided	MR
		70 m	Provided	MR
		1	Provided	MR
		180 lpm	Provided	MR
		70 m	Provided	MR
		2280 lpm	Provided	MR
		70 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		NR	NR	NR
		NR	NR	NR
		NR	NR	NR
		NR	NR	NR
14	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	2,00,000 ltrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		10, 000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts (Pressurization of Lift Lobby & Lift Shaft is not required as the building is low-rise & the lift will run from GF to UFs)			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR

18	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbersNILL.....

Note :- All the shortcomings communicated earlier are complied

Mukesh 28/11/18
 Signature of the Inspecting Officer
 Name SH Mukesh Verma
 Designation DO/W

Udaivir 29/11/18
 Signature of the Inspecting Officer
 Name Udaivir Singh
 Designation ADO/WP

*Dy. HO (W2) Hl Special reg pressurization
 SM-16*
[Signature] 30/11/18

*Do not want - spoken, not required as per table-6
 NBC Part 10 2016.*

Dye HO/W2

[Signature] 1/12/18

*As per table-6 50 Pa pressure
 is required in the Lift Car.*

Do not want / ADO/WP

[Signature] 1/12/18