

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI - 110001



No. FG/DFE/MS/2019/W2/379

Dated: 12/2/19

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Invitee by Clay-1, (Steps Hospitality) located at A-9, Ground Floor and First Floor, Kirti Nagar, New Delhi-110015 in a building comprised of Basement + Ground + 03 Upper Floors owned/ occupied by M/s Invitee by Clay-1, (Steps Hospitality) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 06-02-2019 in the presence of Sh. Tejinder Singh (Partner) and found that the said building that the premises is fit for occupancy class "Assembly" Group D with effect from 12/2/19 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...12/2/19... at New Delhi by.

  
(Atul Garg)  
Chief Fire Officer  
  
12/2/19

Copy to:

1. Sh. Tejinder Singh (Partner),  
M/s Invitee by Clay-1, (Steps Hospitality) A-9, Ground Floor and first Floor,  
Kirti Nagar, New Delhi-110015.
2. Dy. Health Officer, Karol Bagh Zone,  
NDMC, Public Health Department, Karol Bagh, New Delhi.

Following fire safety directives must be adhered to:-

1. **The FSC is valid only for Ground Floor & First Floor only.**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The means of escape shall not be kept locked and remain unobstructed for free movement of occupants in case of an emergency.
8. **Basement will not be used and will be kept sealed as undertaking given by owner/occupier.**
9. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
10. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

