

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/WZ/2019 | 398

Dated: 13/02/2019

FIRE SAFETY CERTIFICATE

Certified that the **Maharaja Aggarsain Adarsh Public School**, located at **DU Block, Pitampura, Delhi - 110034** comprised of Ground + 03 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/SCHOOL/2013/WZ/911 Dated-13-09-2013.. The premises was re inspected by the officer concerned of this department on 03/02/2019 in the presence of Smt Harsh Arya (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 3298-3398 dated 01-03-2011 and that the premises is fit for occupancy class "Educational" Group B with effect from 13/2/19 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on13.2.19... at New Delhi by.

(Atul Garg)

Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Principal, Maharaja Aggarsain Adarsh Public School, D U Block, Pitampura, Delhi - 34.
2. Directorate of Education Old Secretariat Delhi - 110054

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. Basement shall be used strictly as per building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

- Name & address of the building: **Maharaja Aggarsain Adarsh Public School,**
Located at, **DU Block, Pitampura, Delhi – 110034.**
- Type of Occupancy : Educational (Ground + 3 Upper Floor)
- Type of Case : Renewal
- Details of previous NOC : F6/DFS/MS/SCHOOL/2013/WZ/911,Dated13-09-13.
- Fire Safety directives Letter No. : DOE Circular3298-3398 dated 01-03-2011
- Date of inspection : 03/02/2019
- Name of the Inspecting Officer : Udai Vir singh, ADO (WP)
- Name and designation of Officer
from the building side :Smt. Harsh Arya (Principal)
- Year of Construction : 2002
- Applicant's letter No. : MAAPS/2019/1592 Dated 07-01-2019

Plot Area - 16187.4 sqm
Covered Area -6474.97Sqm
No. or Class Rooms-75
No. of Student- 1662

S N o	Minimum standards on fire prevention and fire safety U/R 33	Cr.No.3298- 3398 dated 17- 01-03-2011	Provided at site	Remarks
1.	Access of building			
	• Road width	6 mtr	6 m Provided	MR
	• Gate width	Accessible	06 mtr Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	Three + Ramp	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	3x1.5 mtr	3x148 cm,Ramp- 1x184 cm	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase terrace	2	Provided	MR
	e. Width Of Corridor	1.5 mtr	223cmProvided	MR
	f. Door Size	100cm	Provided(110cm)	MR

3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	22 nos.	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	2	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	Require d	Provided	MR
10	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants:			
	• Size of riser/down- comer	Required	Provided	MR
	• Number of hydrants per floor	Required	Provided	MR
	• Hose Box	Required	Provided	MR
12	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA

13	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		1x450lpm, 1x220 lpm	Provided	MR
		40Mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 	NA	50.000 ltr	NA
		NR	Provided	MR
		NR	Provided	MR
		NR	Provided	MR
		20,000Ltr	Provided (20,000 ltrs)	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA

20	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no.F6/DFS/MS/SCHOOL/2013/WZ/911,Dated-13-09-2013.renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
Name
Designation

[Signature]
Valar Vir Singh
ADD/WP

Signature of the Inspecting Officer
Name
Designation

[Signature]

[Signature]
DFO/WZ
6/2/19

DFO (WZ) - on leave

[Signature]
DFO (WZ)
6/2/19
FIPIS

[Signature]
ADD/WP

As approved by letter is put up
for sign ple. *[Signature]*
12/2/19

[Signature]
DFO

[Signature]