GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2018/SZ/374 **Dated:** 12/2/19

FIRE SAFETY CERTIFICATE

Certified that the **S.L Suri D.A.V. Public Sr. Sec. School,** Chander Nagar, A-Block, Janak Puri, New Delhi-110058, comprised of ground floor plus two upper floors, owned/occupied by S.L Suri D.A.V. Public Sr. Sec. School was issued Fire Safety Certificate by this department vide letter no. F.6/DFS/MS/School/2015/SZ/1434 dated 07.08.15. The School building was re-inspected by the officer concerned of this department on 18.12.2018 in the presence of Smt. Annu Arora (Principal) and found that S.L Suri D.A.V. Public Sr. Sec. School have deemed complied the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class "Educational" for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....12/2/19..... at New Delhi.

(VIPIN KENTAL)
CHIEF FIRE OFFICER

Dc Sz 5/2/19

Copy to:-

1. The Manager,
   S.L Suri D.A.V. Public Sr. Sec. School,
   Chander Nagar, A-Block, Janak Puri, New Delhi-110058

2. Director of Education,
   Govt. of NCT of Delhi, Old Secretariat,
   New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

School building is comprised of ground plus two upper floors.

INSPECTION REPORT

1. Name & address of the building : S.L Suri D.A.V. Public Sr. Sec. School, Chander Nagar, A-Block, Janak Puri, New Delhi-110058
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of Previous NOC : F.6/DFS/MS/School/2015/SZ/1434 dated 07.08.15
5. Fire Safety directives letter No : N/A
6. Date of inspection : 18.12.2018
7. Name of Inspecting Officer : A.D.O. Sandeep Duggal
8. Name and designation of officers From the building side : Smt. Annu Arora (Principal)
9. Year of Construction : 1990
10. Applicant's letter No. : SLSuri/JP/2018/11299 dated 14.11.18

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per FSC dt. 07.08.15/UBBL	Provided at site	Remarks MR/NMR
1.	**Access to building**			
	• Road width	Accessible (06 mtrs.)	Provided 3.95 mtrs	M/R M/R, being old case
	• Gate width	4.5 mtrs	N/A	N/A
	• Width of internal road	N/A		
2.	**Number, Width, Type & Arrangement of Exits**			
	a. Number of staircases			
	• Upper Floors	02 No.'s	Provided	M/R
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floor	150 cms/additional staircase of 75 cms if less than 150 cms	117 & 132 cms	M/R, being old case
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	Required	Provided	M/R
	f. Class Room Door Size	150 cms.	200 cms	M/R
		100 cms	106 cms & 114 cms	M/R
3.	**Compartmentation**			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	**Smoke Management System**			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Natural ventilation provided	M/R
5.	**Fire Extinguishers**			
	• Total numbers	10 no's	Provided	MR
	• Types	ABC/CO_2 type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	**First-Aid Hose Reels**			
	• Total numbers on each floor	02 no.'s	Provided	MR
	• Length of hose reel hose	30 mtrs	Provided	MR

7.	**Automatic fire detection and alarming system**			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	**MOEFA**	N/A	N/A	N/A
9.	**Public Address System**	N/A	N/A	N/A
10.	**Automatic Sprinkler System**			
	• Basement	N/A	N/A	N/A
	• Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	**Internal Hydrants**			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	**Yard Hydrants**			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	**Pumping Arrangements**			
	• Ground Level			
	➢ Discharge of main Pump	N/A	N/A	N/A
	➢ Head of Main pump	N/A	N/A	N/A
	➢ Number of main pumps	N/A	N/A	N/A
	➢ Jockey Pump out put	N/A	N/A	N/A
	➢ Jockey pump head	N/A	N/A	N/A
	➢ Standby Pump out put	N/A	N/A	N/A
	➢ Standby Pump Head	N/A	N/A	N/A
	➢ Auto Starting/Manual Stopping	N/A	N/A	N/A
	➢ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➢ Discharge of pump	450 LPM	Provided	MR
	➢ Head of the pump	40 mtrs	Provided	MR
	➢ Power Supply	Required	Provided	MR
	➢ Auto Starting of pump	Required	Provided	MR
14.	**Captive Water Storage for fire fighting**			
	• Underground tank capacity	N/A	N/A	N/A
	➢ Draw-off connection	N/A	N/A	N/A
	➢ Fire service inlet	N/A	N/A	N/A
	➢ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10000 ltrs	Provided	MR
15.	**Exit Signage.**	Required	Provided	MR
16.	**Provision of Lifts.**			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	N/A	N/A	N/A
17.	**Standby power supply**	N/A	N/A	N/A
18.	**Refuge Area.**			
	➢ Total Area	N/A	N/A	N/A
	➢ Location	N/A	N/A	N/A

2/13

19.	**Fire Control Room**			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	**Special Fire Protection System for Protection of special Risks, if any:**	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter number F.6/DFS/MS/School/2015/SZ/1434 dated 07.08.15 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Note:- As per the undertaking submitted by the Principal of the school (placed at C-28) that the Multipurpose Hall on the second floor has been converted to Extra Curricular Activity Room & the maximum students present at a given time will be less than 45 number at all time. Therefore requirements of MP hall has been removed.

Sandeep 27/12/18

Signature of Inspecting Officer
Name:- Sandeep Duggal
Designation:- Asstt. Divisional Officer

169/DO(SW) dt. 27/12/18

338/cfos2 7/1/21/1/2/19.

Divisional Officer (South West)

27/12/18

DCFO (S2) – C/L

CFO (S2)

what about other short comings.

MS cell

2/1

DCFOS 2

DELHI FIRE SERVICE * Dy. Chief Fire Officer (SZ) 8/1/19 272

DO (SW)

8/1