GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/School/2019/NDZ/ 476 Dated: 7/3/19

FIRE SAFETY CERTIFICATE

Certified that the M/s Arunodaya Public School, at I-A, Karkardooma Institutional area, Vikas Marg Delhi-92, comprised of basement ground plus three upper floors owned/occupied by Arunodaya Public School was issued FSC vide letter no- F6/DFS/MS/School/2016/NDZ/58 Dated 07/01/16. The school building was re-inspected by the team of officers concerned of this department on 01/02/19 in the presence of principal of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Delhi Fire Service Act 2007, and Rules 2010 and observed that the building is fit for occupancy Class B "Educational Building" with effect from ....7/3/19.... for a period of **three** years, subject to conditions printed overleaf.

Issued on.....7/3/19.....at New Delhi by

(Sunil Chawdhary)
Dy.Chief Fire Officer

To,

The Manager,
M/s Arunodaya Public School,
I-A, Karkardooma Institutional area, Vikas Marg Delhi 92.

Copy to:-

The Joint Director of Education(Land & Estate)
Directorate of Education, Lucknow Road, Delhi-54.

CONDITIONS:

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

N/9

1. Name & address of the building : Arunodaya Public School, I-A, Karkardooma Institutional Area, Vikas Marg, Delhi-92.
2. Building is comprised of : B+G+3
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC letter : F6/DFS/MS/School/2016/NDZ/58 Dated: 07/01/2016.
6. Fire Safety direction letter No : Delhi Fire Service Act, 2007 and Rules 2010.
7. Date of Inspection : 01/02/2019
8. Name of the Inspecting officers : DO (East) & ADO (LN)
9. Name and designation of Officer from the building side : (Principal)
10. Year of Construction : 1996
11. Applicant's letter No : Nil Dated - 05/01/19

NO.	Minimum Standards on fire prevention and fire safety U/R33	Requirement as per NBC	Provided at Site	Remark MR/NMR
1	Access to building			
	• Road width	06 Mtrs	30 Mtrs	MR
	• Gate width	4.5 Mtrs	05 Mtrs	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	06 no.	06 Nos.	MR
	• Basement	02 no.	02 Nos.	MR
	b. Width of Staircases			
	• Upper Floor	1.5 m	1.5 mtr each	MR
	• Basement	1.5 m	1.5 mtr each	MR
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	03 no	03 no	MR
	e. Width of Corridor	1.5 m	1.5 m	MR
	f. Door Size	1.0 m	1.0 m	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	55 nos.	55 nos.	MR
	• types	ABC & Co2	ABC & Co2	MR
	• ISI marking	ISI marked	ISI marked	MR

N/10

6	First-aid-Hose Reels.			
	Total numbers of each floor	03 no.	03 no.	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	05 mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	Provided	MR
9	Public address System.	N/A	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➢ Discharge of main Pump	N/A	N/A	N/A
	➢ Head of Main Pump	N/A	N/A	N/A
	➢ Number of main pumps	N/A	N/A	N/A
	➢ Jockey pump out put	N/A	N/A	N/A
	➢ Jockey pump head	N/A	N/A	N/A
	➢ Standby pump out put	N/A	N/A	N/A
	➢ Standby pump Head	N/A	N/A	N/A
	➢ Auto Starting /Manual stopping	N/A	N/A	N/A
	➢ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➢ Discharge of pump	900 LPM x 2	900 LPM x 2	M/R
	➢ Head of the Pump	40 M	40 M	M/R
	➢ Power supply	Required	Provided	M/R
	➢ Auto Starting of pump	Required	Provided	M/R
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	50000 Liters	M/R
	➢ Draw-off connection	N/A	N/A	N/A
	➢ Fire service inlet	N/A	N/A	N/A
	➢ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	15,000 Liters	15,000 Liters	M/R
15	Exit Signage.	Required	Provided	M/R

16	Provision of Lifts. N/A			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The Fire protection systems provided in the building were Tested / Checked and found functional, at the time of inspection.

Keeping in view, of the deemed compliance, of the minimum standards on Fire prevention and Fire safety measures as required under the rules, The Fire safety Certificate issued vide letter no F.6/DFS/MS/School/2016/NDZ/58 dated 07/01/2016 is recommended to renewal under rule 37 of the Delhi Fire Service Rule 2010.

Signature of the Inspecting Officer

Name: F.Brown
DO (East)

Signature of the Inspecting Officer

7/2/2019

Name: R.K. Yadav
Designation: ADO (L N)

08/2

DCFO/NDZ

CFO - M.Sell

FTM.
26/2

379/CFO(NDZ)
28/02/19

Sry FT Letter is put up for sgw pt

5/3/2019

Dy. CFO(NDZ)