

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001


No. F6/DFS/MS/School/2019/NDZ/ 505

Dated: 12/3/19

FIRE SAFETY CERTIFICATE

Certified that the Bharti Public School at New Kondli, Mayur Vihar-III, Delhi-96, owned/occupied by Bharti Public School, comprised of ground plus three upper floors was issued Fire Safety Certificate vide letter no. F.6/DFS/MS/School/2015/2152 Dated 10/12/15. The school building was inspected by the officer concerned of this department on 28/12/18 & 01/02/19 in the presence of Smt. Shalini Sabarwal (Principal) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular no.262-362 Dated 17.01.2005 issued by the Director of Education and found that the building is fit for occupancy class B "Educational Building" with effect from12/3/19..... for a period of three years, subject to conditions printed overleaf.

Issued on12/3/19..... at New Delhi by


(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service



To,

The Principal,
Bharti Public School at New Kondli,
Mayur Vihar-III, Delhi-96.

Copy to:-

The Director of Education
EDMC Plot No. 419, Udyog Sadan,
Patpargang Industrial Area, Delhi-92.

- Conditions -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building : Bharti Public School, New Kondali,
Mayur Vihar-III, Delhi-96.
2. Building is comprised of : Ground plus three upper floors
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6/ DFS/MS/School/2015/NDZ/ dt-10/12/15
6. Fire Safety direction letter No : circular no.262-362 Dated 17.01.2005
7. Date of Inspection : 27/12/18 & 01/02/19
8. Name of the Inspecting officers : ADO R.K. Yadav
9. Name and designation of officer
From the building side : Smt. Shalini Sabarwal (Principal)
10. Year of construction : 2002
11. Applicant's letter No : Letter No.-BPS/MV/2018-19/2252,
dated- 30/11/18

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building.			
	• Road width	06 mtr.	100 mtr.	MR
	• Gate width	4.5 mtr.	5.0 mtr.	MR
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper floor	02 Nos.	02 Nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper floor	1.50 mtr.	1.8 mtr. each	MR
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	02 Nos.	02 Nos.	MR
	e. Width of Corridor	01 mtr.	02 mtr.	MR
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers.			
	• Total numbers	23 nos.	23 nos.	MR
	• types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

112


06	First-Aid-Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 No.	02 No. provided	MR
		30 mtr.	provided	MR
		05 mm	provided	MR
07	Automatic Fire Detection and Alarming System.			
	<ul style="list-style-type: none"> Type of detectors Location of main panel Location of repeater panel Alternate source of power Hooter's location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	N/A	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement upper floor sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> size of riser/down-comer Number of hydrants per floor Hose box 	100 mm	100 mm	MR
		01 No.	02 No.	MR
		01 No.	02 No.	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose box 	N/A	N/A	N/A
		N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	<ul style="list-style-type: none"> Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby pump out put Standby pump head Auto starting /manual stopping Pump house access 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	➤ Terrace Level			
	<ul style="list-style-type: none"> Discharge of pump Head of the pump Power supply Auto Starting of pump 	450 Lpm.	450 Lpm.	MR
		40 M	40 M	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	50,000 ltrs.	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		5,000 Ltr.	10,000 Ltr.	MR
15	Exit Signage.	Required	Provided	MR


Handwritten signature


16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked at the time of inspection. The school building was issued FSC issued vide letter no. F6/DFS/MS/School/2015/NDZ/2152 dated 10/12/15.

Keeping in view the deemed compliance of minimum standards on fire prevention and fire safety required under circular no. 262-362 dated 17/01/2005, it is recommended.



 Signature of the Inspecting Officer
 Name- R.K. Yadav
 Designation- A.D.O.

DO(ED)

 5/2/19.

DY CFO/NDZ


878/CFO(NDZ)
 14/02/19.

C.F.P - Pl put up on previous file.

DCFO/NDZ


14/2

DO/Edy File is not traceable in
 MS cell. If we find we attach with this