

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2019 / 502

Dated 12/3/2019

FIRE SAFETY CERTIFICATE

Certified that the **McDonalds Family Restaurant located on ground floor of M2K Mangalam Place, Sector-3, Rohini, Delhi-110085** was granted NOC by this department vide letter no. **F6/DFS/MS/EH/2016/WZ/182 dated 28/01/2016**. The premise was re-inspected by the officers concerned of this department on **21.02.2019** in the presence of **Mrs. Shilpa Thakur (Manager)** and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy **Class Group-D (Assembly)** with effect from - 12/3/19 for a period of **03 (Three) years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The use of basement shall be in accordance with the provision contained in UBBL 2016/ NBC Part 4, 2016.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
9. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

Issued on12/3/19..... at New Delhi by


(Atul Garg)
Chief Fire Officer
Ph-011-23414250

Copy to:-

1. The Dy. Health Officer, Rohini Zone, Health Department MCD, Sec-5, Rohini, Delhi.
2. McDonald's Family Restaurant at 16, M2K Mangalam Place, DDA Market, Sec-03, Rohini, Delhi-110085.

2/19

INSPECTION REPORT

1. Name & address of the building : McDonald's Family Restaurent at 16, M 2 K Mangalam Place, Sce-3, Rohini, Delhi.
2. Type of Occupancy :Class-D (Assembly)
3. Type of Case :Renewal (Ground floor Only)
4. Details of previous NOC :F6/DFS/MS/EH/2016/WZ/182 dated 28.01.2016
5. Fire Safety directives letter No :Nil
6. Date of inspection :21.02.2019
7. Name of the Inspecting Officers :ADO (RN)
8. Name and designation of officers from the building side : Miss Shilpa Takhur, Manager
9. Year of Construction : 2007
10. Applicant's letter No. : Nil Dated 21.01.2019

	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ BBL Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06m	06m	MR
		Directly Accessible	Directly Accessible	MR
		NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	NA	NA	NA
	b. Width of staircases	NA	NA	NA
	<ul style="list-style-type: none"> • Upper Floors • Basements 	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
		02 Exits	1.35m & 90cm	MR(old case)

3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	04nos	06nos	MR
	• Types	ABC/Co2	ABC	MR
	• ISI marking	Yes	Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	01	MR
	• Length of hose reel hose	30 m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	Smoke/Heat	Provided	MR
	• Location of Main Panel	On GF	Provided	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	On GF	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants (Common with mall)			

2/11

	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	150mm	Provided	MR
		01	Provided	MR
		01	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA	Provided	NA
		NA	Provided	NA
13	Pumping Arrangements. (Common with Mall)			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 			
		2850 lpm	Provided	MR
		60m	Provided	MR
		02	Provided	MR
		180 lpm	Provided	MR
		60m	Provided	MR
		2850 lpm	Provided	MR
		60m	Provided	MR
		Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14	Captive Water Storage for fire fighting. Common with Mall			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	60,000 ltr Common with mall	MR
		NA	Provided	MR
		NA	Provided	MR
		NA	Provided	MR
		10,000 ltr	20,000ltr Common with mall	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft 	NA	NA	NA

0/12

	<ul style="list-style-type: none"> • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17	Standby power supply	Required	Provided with mall	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	Required	On G.F Provided with mall	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	MR
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested/ checked and found some in working order at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate issued vide this department letter of even no. 182 dated 28.01.2016 under rule 35 of the Delhi Fire Service Rules 2010.

14/01/19

Signature of the Inspecting Officer
 Name: - Rajesh Kumar
 Designation:- ADO/RN

Dy Insp / W2

[Signature]
 5/8/19

CFR / W2
[Signature]
 11/3/19

[Signature]

CFR / W2
[Signature]
 18/12/18

As approved, F.T. Letter is being for your signature pl.

18/11/19