

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/EH/2019/SZ/ 635

Dated: 26/3/19

FIRE SAFETY CERTIFICATE

Certified that M/s Pyramids (Tonino) Restaurant located at Khasra No-76/27, Andheria More, Mehrauli, New Delhi-110030, comprised of ground floor only was issued FSC by this department vide letter No. F6/MS/DFS/SZ/EH/2016/630 dated 22/04/2016. The restaurant premise was re-inspected by officer concerned of this department on 14/03/2019 in the presence of Mr. Vijay Kr. Joshi (Gen. Manager) of the restaurant and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Assembly, Group-D" (Restaurant) with effect from 26/3/2019 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 26/3/19 at New Delhi by


(Atul Garg)
Chief Fire Officer
Ph: 011-23414250


Copy to: -

1. The DHO, South Delhi Municipal Corporation, Public Health Department, South Zone, Aurobindo Marg, Green Park, New Delhi.
2. Authorized Signatory, M/s Pyramids (Tonino) Restaurant at Khasra No-76/27, Andheria More, Mehrauli, New Delhi-110030

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

