

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001


No. F.6/DFS/MS/B/SZ/2019/ 638

Dated: 26/3/19

FIRE SAFETY CERTIFICATE

Certified that the **School of Language, Literature & Culture Studies (SLL & CS)** situated at JNU, New Delhi-110067 Comprises of Ground & Three Upper floors was granted FSC by this department vide letter No. F6/DFS/MS/2014/SZ/1600 dated 19/12/2014. The premises was re-inspected by the officer concerned of this department on 14/03/2019 in the presence of Sh. B. S. Rawat (EEE) and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class "**Educational**" with effect from 26/3/ 2019 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on.....26/3/19.....at New Delhi by.


(Rajesh Panwar)
Dy. Chief Fire Officer
Ph: 011-26189168

Copy to:-

1. The Registrar, JNU, New Delhi-110067
2. The Executive Engineer (Bldg.), SDMC, Jal Vihar, Lajpat Nagar, New Delhi-110024

Conditions for the validity of fire safety certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration **every year** in **Form 'K'** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry."

