

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

Fax No. 011-23412593, Ph. 011-26189168

No. F.6 DFS/MS/School/2019/SZ/ 621

Dated: 26/3/19

FIRE SAFETY CERTIFICATE

Certified that the SDMC Primary School located at Kishangarh, New Delhi-110070, comprised of two blocks each ground plus one upper floor was issued FSC by this department vide letter No. F.6/DFS/MS/SZ/School/2016/278 dated 19/02/2016. The said premises was re-inspected by officer concerned of this department on 21/02/2019 in the presence of Mrs. Asha Rani (Principal) and found that school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education circular no. F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education, Govt. of NCT of Delhi and that the school building is fit for occupancy class "Educational Building" Group-B, with effect from the date of issue of this certificate for a period of **Three years** subject to compliance of the conditions given below.

Issued on 26/3/19 at New Delhi by

(Rajesh Panwar)
Dy. Chief Fire Officer

Copy to: -

1. The Principal, SDMC Primary School, Kishangarh, New Delhi-110070.
2. Directorate of Education, South MCD, Civic Centre, Minto Road, New Delhi.-110002

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

