GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/2019/ 743 Dated :---------- 5/4/19

FIRE SAFETY CERTIFICATE

Certified that the **Salute India Deluxe Guest House** located at **8182, Gali No. 6, A. K. Road, Pahar Ganj, New Delhi** comprises of **Ground + 04 Upper floor, Ground floor (Reception + 02 guest rooms), 1st floor to 4th floor (03 guest rooms at each floor), total 14 guest** was granted FSC by this department vide letter No.F6/DFS/MS/GH/2015/NDZ/1655 dated 11/09/2015. The premises was re-inspected by the officer concerned of this department on 13/03/2019 in the presence of Sh. Sanjay and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential Group A-1 as above 14 guest rooms only** with effect from ----5/4/19---- 2019 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on .....5/4/19..... at New Delhi by.

5/4

(Sunil Chowdhary)
Dy. Chief Fire officer
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi.
2. The Manager,
   Salute India Deluxe Guest House, 8182, Gali No. 6, A. K. Road, Pahar Ganj, New Delhi.
3. The Commissioner North MCD.....with a request to get the height of the building measured and intimate to this department for taking further action at our end, if any.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any flammable material for interior decoration is prohibited.

N/25

INSPECTION REPORT

1. Name & address of the building — Salute India Deluxe Guest House at 8182, Gali No. 6, A. K. Road, Pahar Ganj, New Delhi
2. Type of occupancy:- — Residential, Sub Division-A-1
   Gr. + 04 Upper floors (total 14 Guest rooms)
   Ground floor (Reception + 02 guest rooms), 1st floor to 4th floor (03 guest rooms at each floor)
3. Type of case:- — Renewal
4. Details of previous NOC:- — F6/DFS/MS/GH/2015/NDZ/1655 dated 11/09/2015.
5. Fire safety directives No.- — N/A
6. Date of inspection:- — 13/03/19
7. Name of the inspecting officer:- — Sh. Manoj Kumar Sharma (ADO/CC)
8. Name & designation of officer From the building side:- — Sh. Sanjay
9. Year of construction:- — 2001
10. Applicant's letter No:- — Nil dated 12/02/19

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing fire safety arrangemsnts	Provided at site	Remarks MR/NMR
1.	**Access to Building**			
	1) Road width	N/A	06 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3)Width of internal road	N/A	N/A	N/A
2.	**Number, Width Type & Arrangement of Exits**			
	A. Number of staircases			
	1. Upper floors	01 Nos.	01 Nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	0.80 mtr.	1.20 mtr.	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1 mtr.	1 mtr.	MR
3.	**Compartmentation**			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	**Smoke Management System**			
	1) Basements	NA	N/A	N/A
	2) Upper floors	12 ACPH	Natural Ventilation	MR

Mr

5.	**Fire Extinguishers**			
	1) Total numbers	12 Nos.	12 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	**First-Aid Hose Reel**			
	1) Total number of eachfloor	01	01	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	**Automatic Fire Detection & Alarming System**			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	**MOEFA**	N/A	N/A	N/A
9.	**Public Address System**	Required	Provided	MR
10.	**Automatic Sprinkler System**			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	**Internal Hydrants**			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	**Yard Hydrants**			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	**Pumping Arrangement**			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	225 LPM	225 LPM	MR
	b) Head of pump	30 mtr.	30 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR

N/27

14.	**Captive Water Storage for Fire Fighting**			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	2500 ltr.	2500 ltr.	MR
15.	**Exit Signage.**	Required	Provided	MR
16.	**Provision of Lifts.**			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	**Stand by Power Supply**	Required	Provided	MR
18.	**Refuge Area**	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	**Fire Control Room**	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	**Special Fire Protection System for Protection of special Risk, if any:**			NA

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/GH/2015/NDZ/1655 dated 11/09/2015 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer

Name :- M.K. Sharma
Designation :- ADO (CC)

01/04

DO(CC)

F.T. please

DEFO(NDZ)