

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001.

No.F.6/DFS/MS/EH/2019/SZ/ 806

Dated: 12/4/19

FIRE SAFETY CERTIFICATE

Certified that the **M/s Bemisaal Reloaded (a unit of Bemisaal food company)**, B-26, 27, GF & FF, B-Block, Community Centre, Janakpuri, New Delhi-110058, comprised of basement, ground floor plus three upper floors but restaurant is running at ground floor and first floor only, was issued FSC by this department vide letter no. F6/DFS/MS/EH/2016/SZ/305 dated 24.02.2016 owned/occupied by M/s Bemisaal Reloaded (a unit of Bemisaal food company). The restaurant building was re-inspected by the officers concerned of this department on 28.03.2019 in the presence of Sh. Anil Chaudhary (Owner) and found that Management of M/s Bemisaal Reloaded (a unit of Bemisaal food company) have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises (**Ground Floor & First Floor Only**) is fit for occupancy class Group-D "Assembly Building" w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....12.4.19..... at New Delhi.

(ATUL GARG)  
CHIEF FIRE OFFICER

Copy to:-

1. The Manager,  
Bemisaal Reloaded (a unit of Bemisaal food company), B-26, 27,  
GF & FF, B-Block, Community Centre, Janakpuri, New Delhi-110058
2. The Dy. Health Officer,  
S.D.M.C, Public Health Department, West Zone,  
Vishal Enclave, Rajouri Garden, New Delhi-110027

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

A2006p.



## INSPECTION REPORT

1. Name & address of the building : Bemisaal Reloaded (a unit of Bemisaal food company), B-26, 27, GF & FF, B-Block, Community Centre, Janakpuri, New Delhi-58
2. Type of Occupancy : Group D (Assembly Building)
3. Type of Case : Renewal
4. Details of Previous NOC : F6/DFS/MS/EH/2016/SZ/305 dated 24.02.2016
5. Fire Safety directives letter No : N/A
6. Date of inspection : 28.03.2019
7. Name of Inspecting Officers : D.O. M.K. Chattopadhyay & A.D.O. Sandeep Duggal
8. Name and designation of officers  
From the building side : Sh. Anil Chaudhary (Owner)
9. Year of Construction : Before 2003
10. Applicant's letter No. : Nil dated Nil

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	09 mtrs N/A N/A	12 mtrs Directly accessible from road N/A	MR N/A N/A
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	02 no.'s N/A	Provided N/A	MR N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	150 cms & 100cms N/A	190 & 120 cms 190 & 120 cms	MR N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	N/A	One	N/A
	e. Width of Corridor	N/A	Opening in hall	N/A
	f. Door Size	Two exits	200, 165 & 93 cms on GF and 190, 188 & 104 cms on FF	MR, being old case
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	<b>Smoke Management System</b>			
			<b>Restaurant is running at GF &amp; FF</b>	
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	Required	Provided	MR
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	06 No.'s ABC/CO <sub>2</sub> ISI marked	Provided Provided ISI marked	MR MR MR
6.	<b>First-Aid Hose Reels</b>			
			<b>Restaurant is running at GF &amp; FF</b>	
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	One 30 mtrs 5 mm	Provided Provided Provided	MR MR MR



Automatic fire detection and alarming system				
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	N/A	Smoke detector provided	N/A
		N/A	G Floor	N/A
		N/A	N/A	N/A
		N/A	Provided	N/A
			At exit	N/A
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	N/A	N/A	N/A
10.	<b>Automatic Sprinkler System</b>	<b>Restaurant is running at GF &amp; FF</b>		
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N/A	Provided	N/A
	<ul style="list-style-type: none"> <li>Ground Floor &amp; First Floor</li> </ul>	N/A	Provided	N/A
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
11.	<b>Internal Hydrants</b>	<b>Restaurant is running at GF &amp; FF</b>		
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	100 mm	Provided	MR
	<ul style="list-style-type: none"> <li>Number of hydrants</li> </ul>	01 No.	Provided	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	01 No.	Provided	MR
12.	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	N/A	N/A	N/A
13.	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> </ul> </li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual Stopping</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Pump House Access</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	450 LPM & 180 LPM	900 LPM provided	MR
		30 mtrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity <ul style="list-style-type: none"> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		10000 ltrs	15000 ltrs	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>	<b>Restaurant is running at GF &amp; FF</b>		
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	<b>Standby power supply</b>	Required	Provided	MR
18.	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>Total Area</li> </ul>	N/A	N/A	N/A

2/18

19.	<b>Fire Control Room</b>	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Battery backup</li> <li>• Building Floor Plans</li> </ul>	N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>				

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/DFS/MS/EH/2016/SZ/305 dated 24.02.2016, renewal under rule 37 of the Delhi Fire Service rules 2010 is recommended.

*[Handwritten signature]*

Signature of Inspecting Officer  
 Name:- M.K. Chattopadhyay  
 Designation:- Divisional Officer

*Sandeep*  
*03/4/19*

Signature of Inspecting Officer  
 Name:- Sandeep Duggal  
 Designation:- Asstt. Divisional Officer

Dy. C.F.O. (South Zone)



*Comp*  
*5/4*  
*CFo*  
*5/4/19*  
*FTPS*

*DO/5/4* *[Signature]* *10/4/2018*

Add (FCR) → *f.T letter is put up for signature of [Signature]*  
*Sandeep*  
*11/4/19*