

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001


No.F6/DFS/MS/Hospital/2019/NDZ/ 809

Dated: 12/4/19

FIRE SAFETY CERTIFICATE

Certified that the Dharamshila Narayana Superspeciality Hospital (Previously known as Dharamshila Hospital and Research Centre) at Vasundhara Enclave, Delhi, owned/occupied by A Unit of Dharamshila Cancer Foundation and Research Centre comprised of basement, ground plus five upper floors was granted FSC vide letter no. No.F.6/DFS/MS/2016/Hospital/1036 dated 15/06/16. The institutional building was inspected by the officer concerned of this department on 08/03/19 in the presence of Mr. Avinash Singh (Maintenance Manager) and found that the institutional building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and that the building is fit for occupancy Group C "Institutional Building" with effect from12.4.19... for a period of **three** years, subject to compliance of the conditions printed overleaf.

Issued on12/4/19..... at New Delhi by


(Atul Garg)
Chief Fire Officer

To,

1. The Executive Director,
Dharamshila Narayana Superspeciality Hospital,
Vasundhara Enclave, Delhi.

Exh
CONDITIONS:

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. All comments/ directions of the Licensing Department shall always be permitted and followed.
7. The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

N/23
INSPECTION REPORT

1. Name & address of the building : Dharamshila Narayana Superspecial ty Hospital(A Unit of Dharamshila Cancer Foundation and Research Centre) at Vasundhara Enclave,Delhi.
2. Building Comprised of :New Building B,G+5, Old Building B, 3+4 Upper floors,(both bldgs. Are connected to each other)
3. Type of Occupancy : Institutional(Hospital)
4. Type of Case :Renewal
5. Details of Previous NOC :F.6/DFS/MS/Hospital/2016/1036 dated 15/06/16
6. Fire Safety direction letter No : F6/MS/DFS/HOSPITAL/BP/2005/966 dated 06.05.2005
7. Date of Inspection : 08/03/19
8. Name of the Inspecting Officers : ADO R.K. Yadav
9. Name of the designation of Officer
From the building side : Sh. Avinash Singh(Maintance Manager)
10. Year of Construction : 1990 & 2005
11. Applicant's letter No : Nil dated 08/02/19

S.NO.	Minimum Standards on fire prevention and fire safety U/R33	NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	30 m	45 m	MR
	• Gate width	6 m	6 m	MR
	• Width of internal road	6 m	Provided	MR
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	7 nos.	Provided	MR
	• Upper Floor	7nos.	Provided	MR
	• Basement	7 nos.	7 nos.+1 Ramp	MR
	B. Width of Staircases			
	• Upper Floor	1.5 M & 2.0 M	2.0 M& 1.5 M(in old bldg.)	MR
	• Basement	1.5 M & 2.0 M	2.0 M& 1.5 M(in old bldg.),1 Ramp 4m	MR
	c. Protection of exits	Required	Provided	MR
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	e. No. of continuous staircases to terrace	7 nos.	7 nos.	MR
	g. Width of Corridor	2.4 m	Provided	MR
	h. Door Size	2 m, 1 m	2 m, 1 m	MR
3	Compartmentation.	Required	Provided	
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire rating of shaft door	1 hr	1 hr	MR
	• Water curtain	N.A	N.A	N.A
	• Fire Dampers	N.A	N.A	N.A
4	Smoke Management System.	Ventilated		
	• Basement	30a/c per hour	ventilated Exhaust fan	MR
	• Upper floor	12 a/c per hour	ventilated Exhaust fan	MR
5.	Fire Extinguisher			
	• Total numbers	55 nos.	160 nos.	MR
	• Types	Co2 & ABC	Co2 & ABC	MR
	• IS marking	ISI marked	ISI marked	MR

Res

M24

		Required	Provided	
6	First-aid-Hose Reel			
	• Total numbers of each floor	4 nos.	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.	Required	Provided	
	• Type of detectors	Heat & Smoke	Provided	MR
	• Location of main panel	Control room	Control room	MR
	• Location of repeater panel	N.A	N.A	N.A
	• Alternate source of power	Yes	2) 125 KVA	MR
	• Hooters's location	Yes	Different Location	MR
8	MOEFA	Required	Provided	MR
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System	Required	Provided	
	• Basement	Required	Provided	MR
	• upper floor	Required	Provided	MR
	• sprinkler above false ceiling	N.A	N.A	N.A
11	Internal Hydrants	Required	Provided	
	• size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	4 nos.	Provided	MR
	• Hose Box	4 nos.	Provided	MR
12	Yard Hydrants.	Required	Provided	
	• Total number of hydrants	11 nos.	Provided	MR
	• Hose Box	11 nos.	Provided	MR
13	Pumping Arrangements.	Required	Provided	
	• Ground Level
	➤ Discharge of main Pump	2280 LPM	Provided	MR
	➤ Head of Main Pump	70 m	Provided	MR
	➤ Number of main pumps	1 nos.	Provided	MR
	➤ Jockey pump out put	225 LPM	Provided	MR
	➤ Jockey pump head	70 m	Provided	MR
	➤ Standby Pump out put	2280 LPM	Provided	MR
	➤ Standby Pump Head	70 m	Provided	MR
	➤ Auto Starting /Manual stopping	Required	Provided	MR
	➤ Pump House Access	Yes	Provided	MR
	• Terrace Level			
	➤ Discharge of pump	2X900LPM	Provided	MR
	➤ Head of the Pump	40 M	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

W/25

14	Captive Water Storage for Fire Fighting.	Required	Provided	
	• Underground tank capacity	200000 Liters	Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	25,000 Liters	50,000 Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	Required	Provided	
	• Pressurization of Lift Shaft	Required	Provided	MR
	• Pressurization of Lift lobby	Required	Provided	MR
	• Communication in lift car	Required	Provided	MR
	• Firemen's grounding switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.	N/A		
	• Total area	N.A	N.A	N.A
	• Location	N.A	N.A	N.A
19	Fire Control Room	Required	Provided	
	• Detector system panel	Required	Provided	MR
	• Flow switch panel	Required	Provided	MR
	• PA system panel	Required	Provided	MR
	• Battery backup	Required	Provided	MR
	• Building Floor Plans	N.A	N.A	N.A
20	Special Fire Protection systems for protection of special Risks, if any:	N.A	N.A	N.A

Previously the Dharamshila Hospital and Research Centre running at the same address. FSC issued vide letter no. F.6/DFS/MS/Hospital/2016/NDZ/1036 dated 15/06/16 and now management has changed the name of the Hospital i.e. Dharamshila Narayana Superspeciality Hospital .

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

R.K. Yadav
13/2/19

Signature of the Inspecting Officer

Name R.K.Yadav

Designation : ADO(LN)

*DO (ED) on leave
by CFO (ED)*

14/3

DO (ED) / (ED) / (ED) / (ED) / (ED)