

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001



NO. F6/DFS/MS/CGHS/2019/SZ/ 810

Dated: 12/4/19

FIRE SAFETY CERTIFICATE

Certified that the Krishna Apartments having eight blocks, comprised of Ground/Stilt plus five/six & seven upper floors owned/occupied by The Suraksha Sadan CGHS Ltd. Plot No. 13, Sector-9, Dwarka, New Delhi-110077, was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/CGHS/99/2970 dated 26.03.1999. The said premises was re-inspected by the officer concerned of this department on 3.4.2019 in presence Sh. Dinesh Kumar (Secretary) & Navin Kumar (Member) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises / building is fit for occupancy of class A-4, Residential Building (Apartment) with effect from12/4/19.... for a period of **Five years** subject to compliance of the conditions printed overleaf.

Issued on12/4/19..... at New Delhi by


(Atal Garg)
Chief Fire Officer


Copy to:-

- 1 The Hon. Secretary, Krishna Apartments, The Suraksha Sadan CGHS Ltd., Plot No. 13, Sector-9, Dwarka, New Delhi-110077.
- 2 The Joint Director, (L&I) Bldg. DDA Building Section, Vikas Sadan, INA, New Delhi.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. 6 Mts. Wide Access roads for movement of fire units in case of emergency all around the building shall be kept free from any hindrance.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
1. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
2. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
3. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
4. All comments / directions of licensing Department shall always be permitted and followed.
5. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
6. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.


1	Name & address of the building	Krishna Apartments Suraksha Sadan CGHS Ltd., Plot No.13, Sector-9, Dwarka Phase-1, New Delhi- 110077.		
2	Type of Occupancy	Residential Building "A" (Apartment)		
3	Type of case	Renewal	Stilt/Ground plus seven/six/five upper floors	Eight Blocks
4	Details of previous NOC	F6/DFS/MS/CGHS/99/2970 Dated 26.03.1999		
5	Fire safety directives letter No	F6/DFS/MS/95/CGHS/660 dated 25.05.1995		
6	Date of inspection	3.4.2019		
7	Name of the inspecting Officers :	ADO SP Bhardwaj		
8	Name and designation of officers from the building side	Sh. Dinesh Kumar (Secretary) Sh. Navin Kumar (Member)		
9	Year of construction	1999		
10	Applicant's letter No.	SSCGHS/Fire/02/ 18-19 dated 5.3.2019	Stilt/Ground plus five/six/seven upper floors	Eight blocks
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement letter dated 26.03.1999	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	9 Mtrs.	Provided	MR
	2) Gate width	4.5 Mtrs.	Provided	MR
	3) Width of internal road	6 Mtrs.	Provided	MR
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	One	One	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.25 Mtr. each block	Provided	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	One each block	Provided	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	N/A	N/A	N/A
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	Required	Provided	MR
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	N/A	N/A	N/A
	upper floors	12 a/c per hour	Natural Ventilation	MR



	total numbers	2 Nos. each floor each block	Provided	MR
	Types	CO2,ABC,WCO2	Provided	MR
	ISI marking	ISI Marked	Provided	MR
6	First-Aid Hose Reels.			
	total numbers on each floor	One each block	Provided	MR
	Length of Hose reel hose	30 m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	100 mm	Provided	MR
	Number of Hydrants per floor	One each block	Provided	MR
	Hose Box	Required	Provided	MR
12	Yard Hydrants.			
	Total number of hydrants	2 Nos.	Provided	MR
	Hose box	Required	Provided	MR
13	Pumping arrangements			
	1. Ground level/			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450 LPM each block	Provided	MR
	b. head of the pump	35 Mtrs.	Provided	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	2,00, 000 Ltrs.	Provided	MR
	a. Draw-off connection	Required	Provided	MR
	b. fire service inlet	Required	Provided	MR
	c. Access to tank	Required	Provided	MR
		10 000 ltrs. each		



4/18

15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	Required	Provided	MR
	d. Fireman's grounding switch	Required	Provided	MR
	e. Lift signage	Required	Provided	MR
17	Standby power supply	Required	DG Set	MR
18	Refuge Area.	Not Required		
	total area	N/A	N/A	N/A
	location	N/A	N/A	N/A
19	Fire control room			
	a. Detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	Required	Provided	MR
20	Special Fire Protection systems for protection of special risks, if any:	Required	CO2 fire extinguisher provided near electrical panel	MR

Fire Protection systems were checked found functional at the time of inspection Shortcomings issued vide letter no. F6/DFS/MS/CGHS/SZ.2018/4914 dated 7.12.2018 found rectified.
 Keeping in view deemed compliance of the minimum standards on fire prevention & fire safety requirements under the rules renewal of FSC issued vide letter no. F6/MS/DFS/CGHS/99/2970 dated 26.3.1999 is recommended.
 Accordingly DFA is put up for approval and signature please.


 S P Bhardwaj
 ADO (DWARKA)



 DC (S2)



 10/4/19
 Anil

