

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2019 / *School/WZ/880*

Dated: *23 / 4 / 2019*


FIRE SAFETY CERTIFICATE

Certified that the **Delhi Heritage School** located at **Main Kanjhawala Road, Sector-22, Rohini, Delhi-110085** comprised of **02 block -B+G + 03 upper floor & G+03 floor** owned/ occupied by **Delhi Heritage School** was issued Fire Safety Certificated vide this office letter no. **F-6/DFS/MS/School/2014/WZ/1167 dated 11.09.2014 & F.6/DFS/MS/2016/WZ/987 dated 09.06.2016**. The premise was re-inspected by the officer concerned of this department on **19.03.2019** in the presence of **Sh. Vibha Gupta** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition and there is no additional construction. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under **Educational "Group B"** with effect from *...23/4/19.....* for a period of **three years** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on *..23/4/19.....* at New Delhi


(Dharmpal Bhardwaj)
Dy. Chief Fire Officer
Ph:-011-25104544

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Delhi Heritage School, Main Kanjhawala Road, Sector-22, Rohini, Delhi.

INSPECTION REPORT

1. Name & address of the building : Delhi Heritage School, Main Kanjhawala Road, Sector-22, Rohini , Delhi-110085.
2. Type of Occupancy : Educational
3. Type of Case : Renewal 02 blocks(B+G + 03 upper floors & G+03 floors)
4. Details of previous NOC : F6/DFS/MS/School/2014/WZ/1169 Dated: 11/09/2014 & F6/DFS/MS/School/2016/WZ/987 Dated: 09/06/2016
5. Fire Safety directives letter No : NBC Part 4.
6. Date of inspection : 19/03/2019
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers from the building side : Mrs. Vibha Gupta, Principal
9. Year of Construction : 2004/2015
10. Applicant's letter No. : Nil Dated: 06.02.2019

Plot Area- 2847 m2

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6m	6m	MR
	• Gate width	Directly Accessible	Directly Accessible	MR(Old case)
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Block-A-02 Block-B-02	Block-A-02 Block-B-02	MR
	• Basements	Block-A-02	block-A--02	MR
	b. Width of staircases			
	• Upper Floors	1.50 m	Block-A-165 cm & 91cm Block-B- 122cms,150cms	MR(old case)
	• Basements	Block-A-1.50m	1.50cm & 1.25m	MR(old case)
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace			
		01	02	MR
	e. Width of Corridor			
		NA	NA	NA
	f. Door Size			
		1.0m	1.0m	MR

2/11

3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	19nos	20 nos	MR
	• Types	ABC/Co2	ABC--20	MR
	• ISI marking	Yes	Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	Block-A- 02 Block-B - 01	Block-A- 01 Block-B - 01	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5m	5m	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	100mm	Provided	MR
	• Number of hydrants per floor	01 each block	Provided	MR
	• Hose Box	01 each block	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	01	Provided	MR

	<ul style="list-style-type: none"> • Hose Box 	01	01	MR
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level 			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	900lpm &450lpm	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	A-Block-15,000ltr B-Block- 10000 ltr.	Block-A-15000 ltr Block-B - 10000 ltr.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			

n/13

	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition, at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 17.01.2005/NBC-Part-4, the NOC issued vide letter of even no. 1167 dated 11.09.2014 & 987 dated 09.06.2016, renewal under rule 35 of the Delhi Fire Service Rules, 2010 is recommended.

[Handwritten Signature]

Signature of the Inspecting Officer

Name :- Rajesh Kumar

Designation:- ADO/RN

Dy Chd/W2

[Handwritten Signature]
8/4/19

~~ADO/R.N~~ / F-T

As approved, F.T. letter is put up for your signature pl.

[Handwritten Signature]

Dy Chd/W2

[Handwritten Signature]
22/4/19

ms/cell