

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/WZ/2019/ 844

Dated: 16 /04/2019

FIRE SAFETY CERTIFICATE

Certified that the **M. C. Primary Co – Education School** Located at **Bharat Nagar, Delhi – 110052** comprised of Ground +1 Upper Floor owned/ occupied by **M. C. Primary Co – Education School** have complied with the fire prevention and fire safety requirements in accordance with the Director of Education Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 and verified by the officers concerned of Fire Service on 03/04/2019 in the presence of **Smt. Promila Jain (Principal)** and that the building / premises is fit for the occupancy class “Educational” Group B Sub Division B – 1 with effect from16/4/19... for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on16/4/19.... at New Delhi by.


(Atul Garg)
Chief Fire Officer
Delhi Fire Service

Copy to:

1. M. C. Primary Co – Education School, Bharat Nagar, Delhi – 110052
2. Directorate Of Education Old Secretariat Delhi – 110054

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: **M. C. Primary Co – Education School**
Located at **Bharat Nagar, Delhi – 110052**
2. Type of Occupancy : Educational New Block Ground +1 Upper Floor
3. Type of Case : New
4. Details of previous NOC : Nil
5. Date of inspection : 03/04/2019
6. Name of the Inspecting Officer :Udai vir singh, ADO (WP)
7. Name and designation of Officer
from the building side : Smt. Promila Jain (Principal)
8. Year of Construction : 2018
9. Applicant's letter No. :Nil dated 18/03/2019.

No. of Students=188
No. of class rooms=11
Plot area=2263sqmt
Covered Area—1124qmt

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No.3298-3398 dated 1-3-11	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	<ul style="list-style-type: none"> Accessible Accessible NA 	<ul style="list-style-type: none"> 6 Provided 300 cm Provided NA 	<ul style="list-style-type: none"> MR MR NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper floors Basements 	<ul style="list-style-type: none"> 1 NA 	<ul style="list-style-type: none"> 2 Provided NA 	<ul style="list-style-type: none"> MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper floors Basements 	<ul style="list-style-type: none"> 1.5 mtrs. NA 	<ul style="list-style-type: none"> 1x150 cm & 1x124 cm NA 	<ul style="list-style-type: none"> MR NA
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
	d. No of continuous staircase to terrace			
	<ul style="list-style-type: none"> Width Of Corridor 	<ul style="list-style-type: none"> 1 1.5m 	<ul style="list-style-type: none"> Provided 210cm Provided 	<ul style="list-style-type: none"> MR MR
	f. Door Size	<ul style="list-style-type: none"> 1 mtr 	<ul style="list-style-type: none"> 112cm Provided 	<ul style="list-style-type: none"> MR

3.	Compartmentation				
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
4.	Smoke managements System				
	<ul style="list-style-type: none"> • Basements • Upper floors 	NA	NA	NA	
		NA	NA	NA	
5.	Fire Extinguishers				
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	5 nos. ABC & CO ₂ ISI marked	05 Provided	MR	
			Provided	MR	
			Provided	MR	
6.	First – Aid Hose Reels				
	<ul style="list-style-type: none"> • Total nms on each floor • Length of hose reel hose • Nozzle diameter 	NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
7.	Automatic fire detection and alarming system				
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
8.	MOEFA	NA	NA	NA	
9.	Public Address System	Required	Provided	MR	
10.	Automatic Sprinkler System				
	<ul style="list-style-type: none"> • Basements • Upper Floor • Sprinkler above false ceiling 	NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
11.	Internal Hydrants:				
	<ul style="list-style-type: none"> • Size of riser/down- comer • Number of hydrants per floor • Hose Box 	NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
12.	Yard Hydrants				
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA	NA	NA	
		NA	NA	NA	

13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> • O H/U G tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA
		NA	NA	NA
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbersNil.....

Signature of the Inspecting Officer

Name

Designation

~~12/4/19~~
 Uday Vir Singh
 ADO/WP

Signature of the Inspecting Officer

Name

Designation

I

~~DO/W~~
~~5/4/19~~
 Ex. CFO (W2)
 8/4/19

~~CFO West~~
~~9/4/19~~

~~FT A/S~~
~~ADO/WP~~

Sir AF letter is put up for signature

~~12 CFO~~
~~18/4/19~~

~~12/4/19~~

ml