FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. **F6/DFS/MS/school/2019/** 842 **Dated:** 16 **/04/2019**

FIRE SAFETY CERTIFICATE

Certified that the **Montfort Nursery School** Located at, **NS-29, Kela Godown Road Shalimarbagh, Delhi-110088** comprised of **Ground + 02 Upper Floors** was issued FSC vide Letter No. NoF6/DFS/MS/10/413 Dated10/02/10 The premises was re inspected by the officer concerned of this department on **29/03/19** in the presence of **Bro. Thampy Alex (Director)** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 262-362 dated 17/01/2005 and that the premises is fit for occupancy class "Educational" Group B with effect from 16/4/19 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...16/4/19.... at New Delhi by.

15/4/19

(Dharampal Bhardwaj)
DY. Chief Fire Officer,
Delhi Fire Service.

Copy to:

1. The Principal, Montfort Nursery School Located at NS-29 Kela Godown Road Shalimar bagh, Delhi-110088
2. Directorate of Education Old Secretariat Delhi – 110054

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The Basement shall be used as per BBL1983
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Montfort Nursery School Located at NS-29 Kela Godown Road Shalimarbagh, Delhi-110088
2. Type of Occupancy : Educational (Ground + 2 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : Letter NoF6/DFS/MS/10/413 Dated10/02/10
5. Fire Safety directives Letter No. : 262-362 dated 17/01/2005
6. Date of inspection : 29/03/2019
7. Name of the Inspecting Officer : ADO (WP)
8. Name and designation of Officer from the building side : Bro. Thampy Alex (Director)
9. Year of Construction : 2005
10. Applicant's letter No. : Nil Dated 18/02/2019

Plot Area - 910M^2
Covered Area -909 M^2
No. or Class Rooms-09
No. of Student- 175

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No.3298-3398 dated 01-03-2011	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1	2 Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1x1.50 mtr	158cm &108cm	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NR	NR	NR
	• Pressurization	NR	NR	NR
	d. No of continuous staircase to terrace			
	e. Width Of Corridor	NA	NA	NA
	f. Door Size(**Class room**)	1mtr	1X110 mtr	MR

3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NR	NR	NR
	• Upper floors	NR	NR	NR
5.	Fire Extinguishers			
	• Total numbers	20nos.	Provided	MR ✓
	• Types	ABC & CO_2	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	One at each floor	Provided	MR ✓
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR ✓
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down-comer	Required ?	Provided	MR ?
	• Number of hydrants per floor	Required	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA

13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➢ Head of main pump	NA	NA	NA
	➢ Number of main pumps	NA	NA	NA
	➢ Jockey pump out put	NA	NA	NA
	➢ Jockey pump head	NA	NA	NA
	➢ Standby Pump out put	NA	NA	NA
	➢ Standby Pump Head	NA	NA	NA
	➢ Auto Staring/Manual stopping	NA	NA	NA
	➢ Pump House Access	NA	NA	NA
	• Terrace level			
	➢ Discharge of pump	450 lpm &180 lpm	Provided	MR
	➢ Head of the pump	40Mtr	Provided	MR
	➢ Power supply	Required	Provided	MR
	➢ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➢ Draw off connection	NA	NA	NA
	➢ Fire service inlet	NA	NA	NA
	➢ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5,000Ltr	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➢ Pressurization of Lift Shaft	NA	NA	NA
	➢ Pressurization of lift lobby	NA	NA	NA
	➢ Communication in lift Car	NA	NA	NA
	➢ Fireman's Grounding Switch	NA	NA	NA
	➢ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➢ Total area	NA	NA	NA
	➢ Location	NA	NA	NA
19.	Fire control room			
	➢ Detector system panel	NA	NA	NA
	➢ Flow Switch Panel	NA	NA	NA
	➢ PA System Panel	NA	NA	NA
	➢ Battery backup	NA	NA	NA
	➢ Building Floor Plans	NA	NA	NA

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. NoF6/DFS/MS/10/413 Dated10/02/10 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

5/4/19

Signature of the Inspecting Officer

Name Valar Vir Singh

Designation ADO/WP

Signature of the Inspecting Officer

Name

Designation

DO/W

8/4/19

Dy. CFO(WZ)

10/4/19

ADO/WP / F-T

Sir FY letter is put up for Sign pls

11/4/19

Dy CFO

15/4/19

ADO/WP - / F-T

MS/cell