

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001


NO. F6/DFS/MS/School/2019/SZ/ 877

Dated:- 23/4/19

FIRE SAFETY CERTIFICATE

Certified that the Hira Devi Model School, Mahatma Gandhi Marg F Block, Raj Nagar-II, Palam Colony, New Delhi-110045, comprised of ground plus One upper floor was issued Fire Safety Certificate by this department vide letter No.F6/DFS/MS/School/2015/SZ/584 dated 22.4.2015. The building was re-inspected by the officer concerned of this department on 4.4.2015 in the presence of Sh. Rajbir Singh Yadav (Manager) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education GNCT of Delhi circular No: Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 and that the school building is fit for occupancy of class B "Educational Building" for ground plus one upper floor with effect from 23/4/19 for a period of **three years** subject to compliance of the conditions printed overleaf.

Issued on23/4/19..... at New Delhi by


(Rajesh Panwar)
Dy. Chief Fire Officer

Copy to:-

1. The Director (Education) GNCTD, SDMC, 23rd floor Civic Centre, Minto Road, New Delhi.
2. The Manager, Hira Devi Model School, Mahatma Gandhi Marg F, Block, Raj Nagar-II, Palam Colony, New Delhi-110045.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

1	Name & address of the building	Hira Devi Model School, Mahatma Gandhi Marg F, Block, Raj Nagar II, Palam Colony, New Delhi-110045.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal (G+1)		
4	Details of previous NOC	No.F6/DFS/MS/School/2015/SZ/584 dated 22.4.2015		
5	Fire safety directives letter No	Edu. Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011.		
6	Date of inspection	4.4.2019		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh. Rajbir Singh Yadav (Manager)		
9	Year of construction	2003		
10	Applicant's letter No.	HDMPS/22F/19-20 dated 16.3.2019	(Ground plus one upper floor)	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	DOE CIR. Dated 1.3.2011/ letter dated 22.4.2015	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	6 Mtrs.	Provided	MR
	2) Gate width	4.5 Mtrs.	Direct accessible from road	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	2 Nos.	2 Nos.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.50 Mtrs. if less than 1.50 Mtrs. additional staircase of .75 Mtr. is required	1.22 Mtrs. & 1 Mtr.	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	1 No.	MR
	e. Width of corridor	N/A	1 Mtr. to 1.25 Mtrs.	N/A
	f. Door size	1 Mtr.	80 to 1 Mtr.	MR being old case
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	N/A	N/A	N/A
	upper floors	12 a/c per hour	Natural Ventilation	MR
5	Fire Extinguishers			
	total numbers	4 Nos.	Provided	MR
	Types	CO2 & ABC	Provided	MR
	ISI marking	ISI Marked	Provided	MR


6	First-Aid Hose Reels.			
	total numbers on each floor	N/A	One	Old case
	Length of Hose reel hose	N/A	30 Mtrs.	MR
	Nozzle Diameter	N/A	5 MM	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	180 LPM	Old case
	b. Head of main pump	N/A	30 Mtrs.	MR
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	2500 Ltrs.	Old case
15	Exit Signage.	N/A	N/A	N/A
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

2/8

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area	N/A	N/A	N/A
	location	N/A	N/A	N/A
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: ABC Fire Extinguisher provided near electric Meter	MR		


Fire Protection systems provided in building were checked & found functional at the time of inspection. Keeping in view deemed compliance of minimum standards on fire prevention and fire safety requirements as per DOE Cir. Dated 1.3.2011, renewal of FSC issued vide letter no. F6/DFS/MS/School/2015/SZ/584 dated 12.4.2015 is Accordingly DFA is put up for approval and signature please.

S.P. Bhardwaj
S.P. Bhardwaj
ADO (Dwarka)



DOSW
dy
8/4/2018

DCFO (S2)



dy
9/4
dy
11/4

ADD (DWC)

FT for signature please.



dy
18/4/19

dy

S.P. Bhardwaj
18/4/19