

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F6/DFS/MS/School/2019/NDZ/ 876

Dated:
22/07/19

FIRE SAFETY CERTIFICATE

Certified that the M/s Gyandeeep Vidya Bhawan Sr. Sec. School located at C-10 Yamuna Vihar, Delhi-110053, A-Block comprised of ground plus two upper floors & B-Block ground plus one upper floor, owned/occupied by Gyandeeep Vidya Bhawan Sr. Sec. School was issued FSC vide letter No. F6/DFS/MS/2015/NDZ/2220 dated 21/12/15. The school building was re-inspected by the officer concerned of this department in the presence of Mrs. Beena Bharadwaj, Principal of the school and found that the school have deemed complied with the fire prevention and fire safety requirements in accordance with rules 33 of the Delhi Fire Service Rules, 2010 and observed that the school building fit for occupancy class "B" 'Educational Building' with effect from 22/07/19. for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on.....22/07/19.....at New Delhi by


(Sunil Chawdhary)
Dy.Chief Fire Officer

To,
The Manager,
M/s Gyandeeep Vidya Bhawan Sr. Sec. School
C-10 Yamuna Vihar,
Delhi-110053

Copy:-
The Dy. Director of Education,
B- Block, Yamuna Vihar,
Delhi-110053

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

1. Name & address of the building : Gyandeeep Vidya Bhawan Sr. Sec. School. , C-10 Yamuna Vihar, Delhi-53
2. Building is comprised of : A-Block- G+2 & B-Block-G+1
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6/DFS/MS/2015/NDZ/2220 dated 21/12/15
6. Fire Safety direction letter No : NBC Part-IV
7. Date of Inspection : 05/04/2019
8. Name of the Inspecting officers : ADO Om Prakash
9. Name and designation of Officer from the building side : Mrs. Beena Bharadwaj (Principal)
10. Year of Construction : 1991, 2016
11. Applicant's letter No : Nil, Dated- 07/03/19

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Part-IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building.			
	• Road width	06 mtr.	07 mtr.	MR
	• Gate width	4.50 mtr	4.50 mtr	MR
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper floor	01 No. in each Block	A-Block 02 no. & B-Block 02 nos.	MR
	• Basement	N/A	N/A.	N/A
	b. Width of Staircases			
	• Upper floor			
	• A-Block	1.50 mtr.	1.40 mtr & 1.50 mtr	MR
	• B-Block	1.50 mtr.	1.35 mtr & 0.75 mtr	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	01 No.	01 No. in each Block	MR
	e. Width of Corridor	1.50 mtr.	1.40 mtr to 1.50 mtr.	MR (Old accepted)
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers.			
	• Total numbers	10 nos.	10 nos.	MR
	• Types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

06	First-Aid-Hose Reels.			
	Total numbers on each floor	01 No.	01 No. in each Block	MR
	<ul style="list-style-type: none"> Length of hose reel hose Nozzle diameter 	30 mtr.	30 mtr	MR
		05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	<ul style="list-style-type: none"> Type of detectors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of main panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of repeater panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hooter's location 	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> upper floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> sprinkler above false ceiling 	N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> size of riser/down-comer 	N/A	100 mm	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	N/A	01 no.	MR
	<ul style="list-style-type: none"> Hose box 	N/A	01 no.	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose box 	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	<ul style="list-style-type: none"> Discharge of main pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Head of Main pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Number of main pumps 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Jockey pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Jockey pump head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Standby pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Standby pump head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Auto starting/manual stopping 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pump house access 	N/A	N/A	N/A
	➤ Terrace Level			
	<ul style="list-style-type: none"> Discharge of pump 	450 lpm	450 lpm	MR
	<ul style="list-style-type: none"> Head of the pump 	40 mtr	40 mtr	MR
	<ul style="list-style-type: none"> Power supply 	Required	Provided	MR
	<ul style="list-style-type: none"> Auto starting of pump 	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Draw-off connection 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fire service inlet 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Access to tank 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Overhead tank capacity 	10,000 Ltr.	10,000 Ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pressurization of lift lobby 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Communication in lift car 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Firemen's grounding switch 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Lift signage 	N/A	N/A	N/A

17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the NBC Part IV, it is recommended to renew Fire Safety Certificate.

Om Prakash
11/4/19

Signature of the Inspecting Officer

Name :- Om Prakash

Designation :- A.D.O (Shd)

~~DO(E)~~
for f
12/4/19.
DY. CEO/MDA *sh*
12/4/19

M.S. cell

FT. cell is prepared and put up for District
Plan

DY. CEO/MDA *sh*
22/4
M.S. cell

for f
18/4.